

SEC. 19. *And be it enacted,* That all connections with drain pipes or sewers be in manner as follows: All connections with drain pipes or sewer must be made with "Y" branches one-eighth and one-sixteenth bend, and when a privy or well or cesspool is to be connected to a sewer, private or public, a pipe at least four inches in diameter must be used, and a joint must be formed at least five feet outside the well. The said pipe must be of extra heavy cast iron with a sanitary tee in the well, with the bell standing upright, and at least eighteen inches of pipe on lower end to project down into the water, the upper end to extend as high as the surface of the ground or floor, as the case may be, and securely plugged with a leaf screw ferrule, and so constructed as to be easily cleaned out.

Manner of said connections.

SEC. 20. *And be it enacted,* That all pavements, streets, alleys, roads or ways in any said city or town must be relaid and placed in good condition as soon as practicable after the work is finished, at the expense of the owner of the property or the person or persons having the work done.

Pavements, streets, etc.

SEC. 21. *And be it enacted,* That all drain pipes laid in the public streets, alleys, roads or ways shall be of extra heavy cast iron or vitrified pipe, and connected with the best Portland cement, and must have a fall of not less than one foot to every fifty feet, all exceptions to the preceding rule to be made only with the approval of said Inspector, and all change in direction must be made with curved pipes one-eighth or one-sixteenth bend, and no steam pipe, blow-off, steam-exhaust boiler or drip pipes shall be connected with the house drain or sewer, but all such connections must be made to the main sewer on the outside trap or main drain.

Drain pipes..

SEC. 22. *And be it enacted,* That all joints in vitrified drain pipes shall be made with mortar composed of one part best hydraulic cement and two parts clean, sharp sand, when same is used on or in private ground.

Joints in drain pipes.

SEC. 23. *And be it enacted,* That a running trap of extra heavy pipe with double vent shall be placed on every house sewer at an accessible point, if practicable, within the wall of the building, and a vertical pipe of the same diameter, provided with a brass trap screw, shall be constructed over the trap to admit of cleaning the same.

Running trap and vertical pipe.

SEC. 24. *And be it enacted,* That every house sewer shall be provided with a fresh-air inlet on house side of the running trap of not less than four inches in diameter, of form to be approved by the Inspector of Plumbing, under the direction of

Fresh-air inlet for house sewers.