

## COUNTY LOCAL LAWS

## (15) "SECTION 1002 DESIGN OF BUILDING WATER DISTRIBUTION SYSTEM

WATER PIPING SYSTEMS SHALL BE DESIGNED AND INSTALLED SO THAT THE MAXIMUM VELOCITY AT ANY TIME SHALL NOT EXCEED THE LESSER OF EIGHT FEET (8') PER SECOND, OR TO THE MAXIMUM LIMIT RECOMMENDED BY THE MANUFACTURER OR INDUSTRY STANDARDS."

## (16) "SECTION 1003.1.7 WATER HEATING EQUIPMENT VALVE

THE COLD WATER BRANCH TO EACH HOT WATER STORAGE TANK OR WATER HEATER SHALL BE PROVIDED WITH A VALVE LOCATED NEAR THE EQUIPMENT, WHICH VALVE SHALL ONLY SERVE SAID EQUIPMENT. EACH TANK OR HEATER SHALL BE EQUIPPED WITH AN APPROVED AUTOMATIC RELIEF VALVE AS SPECIFIED IN PARAGRAPH 1005.2."

## (17) "SECTION 1004.11.8 LAWN SPRINKLERS

LAWN SPRINKLER SYSTEMS WHEN CONNECTED TO A POTABLE WATER SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE PROVISIONS OF THIS SUBTITLE. ADEQUATE AND PROPER PROVISION SHALL BE MADE FOR CONTROL AND DRAINAGE, AND TO PREVENT BACKSIPHONAGE. THE WATER SUPPLY LINES MAY BE LAID AT A DEPTH LESS THAN THREE AND ONE-HALF FEET (3 1/2')."

## (18) "SECTION 1201.1 LOSS OF SEAL BY EVAPORATION

FLOOR-DRAIN TRAP SEALS SHALL BE FED FROM AN APPROVED PLUMBING FIXTURE OR BY MEANS OF AN APPROVED AUTOMATIC PRIMING DEVICE OR BY ANY OTHER ARRANGEMENT THAT IS APPROVED BY THE ADMINISTRATIVE AUTHORITY."

## (19) "SECTION 1204.4 SIDE INLET

ALL SIDE-INLET CLOSET BENDS SHALL NOT BE LESS THAN FOUR INCHES (4") IN DIAMETER AND SHALL BE PERMITTED ONLY IN INSTALLATION WHERE THE FIXTURE CONNECTING THERETO IS VENTED; IN NO INSTALLATION SHALL THE INLET BE USED TO VENT A BATHROOM GROUP WITHOUT BEING WASHED BY A FIXTURE."

## (20) "SECTION 1205.1 SINGLE BATHROOM GROUPS TOP FLOOR