

(2) "APPROVED SINK FAUCET FOR A PUBLIC FACILITY" MEANS ANY FAUCET WITH SPRING-LOADED VALVES OR OTHER DEVICES THAT STOP THE FLOW OF WATER UPON RELEASE OF THE HANDLE OR THAT STOP THE FLOW OF WATER AFTER NOT MORE THAN ONE GALLON OF WATER HAS FLOWED THROUGH THE FITTING.

(3) "APPROVED SINK FAUCET FOR PRIVATE USE" MEANS ANY FAUCET USING NO MORE THAN FOUR GALLONS OF WATER PER MINUTE, WITH THE RATE BASED ON A PRESSURE AT THE FIXTURE OF 40-50 POUNDS PER SQUARE INCH.

(4) "APPROVED WATER CLOSET" MEANS ANY WATER CLOSET USING NO MORE THAN 3 1/2 GALLONS OF WATER PER FLUSH, WITH THE RATE BASED ON A PRESSURE AT THE FIXTURE OF 40-50 POUNDS PER SQUARE INCH.

(5) "APPROVED URINAL" MEANS ANY SINGLE, FLUSH-TYPE URINAL USING NO MORE THAN 1 1/2 GALLONS OF WATER PER FLUSH, WITH THE RATE BASED ON A PRESSURE AT THE FIXTURE OF 40-50 POUNDS PER SQUARE INCH.

~~(5)~~ (6) "BUILDING" INCLUDES ANY BUILDING OR STRUCTURE THE INITIAL CONSTRUCTION OF WHICH COMMENCED ON OR AFTER JANUARY 1, 1979.

~~(6)~~ (7) "CONSTRUCTED" MEANS THE BUILDING, INSPECTING AND SUPERVISING OF NEW STRUCTURES AND THE INSTALLING OF EQUIPMENT REQUIRED IN CONNECTION WITH THE NEW STRUCTURES.

~~(7)~~ (8) "LOCAL PLUMBING INSPECTORS" MEANS THE INSPECTORS OF THE APPROPRIATE AGENCIES OR UNITS OF EACH COUNTY AND MUNICIPAL GOVERNMENT IN THE STATE WHO INSPECT THE INSTALLATION OF PLUMBING FIXTURES AND DEVICES AND WATER, DRAINAGE, AND SEWAGE SYSTEMS.

~~(7)~~ ~~(8)~~ (9) "REMODELED" MEANS THE COMPLETE RECONSTRUCTION OR ~~REPLACEMENT OF A PLUMBING FIXTURE~~ OR THE RELOCATION OF A WHOLE PLUMBING SYSTEM TO ANOTHER PART OF A BUILDING.

~~(8)~~ ~~(9)~~ (10) "SECRETARY" MEANS THE SECRETARY OF THE DEPARTMENT OF LICENSING AND REGULATION.

(B) RETAIL SALES. (1) A PERSON MAY NOT SELL ~~AT RETAIL~~ ANY PLUMBING FIXTURE WHICH IS NOT AN APPROVED PLUMBING FIXTURE AS DEFINED IN SUBSECTION (A).

(2) ~~THE SECRETARY~~ LOCAL PLUMBING INSPECTORS SHALL ENFORCE THE PROHIBITION AGAINST THE ~~RETAIL~~ SALE OF ANY PLUMBING FIXTURES WHICH ARE NOT WATER-CONSERVING FIXTURES IN THE INTERESTS OF ENSURING THAT THE CAPACITIES FOR WASTEWATER TREATMENT OF MUNICIPAL SEWAGE TREATMENT FACILITIES AND PRIVATE ON-SITE WASTEWATER DISPOSAL SYSTEMS ARE NOT EXCEEDED.

(C) REQUIRED WATER-CONSERVING FIXTURES AND DEVICES. EXCEPT AS PROVIDED UNDER SUBSECTION (D), THE FOLLOWING