

INTERAGENCY COMMISSION ON SCHOOL CONSTRUCTION



LARRY HOGAN
GOVERNOR

KAREN SALMON, PhD.
CHAIRPERSON

ROBERT A. GORRELL
EXECUTIVE DIRECTOR

200 WEST BALTIMORE STREET
BALTIMORE, MD 21201
410-767-0617

IAC.MARYLAND.GOV

IAC.MSDE@MARYLAND.GOV

The Honorable Larry Hogan
Governor
State House
Annapolis MD 21401

MSAR #9644 - Report on the Evaluation and Intended Use of Solar
Technologies

Interagency Commission on School Construction

May 17, 2019

Education Article § 5-319 requires that:

(A) The Interagency Commission shall adopt regulations that require the design development documents for the construction or major renovation of school buildings submitted by a county board to the Interagency Commission to include:

- (1) An evaluation of the use of solar technologies, including photovoltaic or solar water heating, based on life cycle costs; and
- (2) If an evaluation determines that solar technologies are not appropriate for a construction or major renovation project, a report that explains why the use of the technology is not appropriate.

(B) On or before December 31 of each year, the Interagency Commission shall submit a report on the number of public school construction and major renovation projects in each jurisdiction that use solar technologies to the Governor and, in accordance with § 2-1246 of the State Government Article, the General Assembly.

The Department of General Services or the Maryland State Department of Education reviews the required evaluation and reports during the course of design review. Comments on the inclusion of the evaluations are a standard component of the review letters for new construction or major renovation projects. The primary limitation cited for determining that solar technologies are not appropriate is the lengthy payback for roof mounted photovoltaic panels. Power production is calculated to be low relative to the requirements of a school and to the extent that solar technologies are pursued, it is more for demonstration and educational purposes. The school systems have performed evaluations in accordance with the statute, and Department of General Services has reviewed the evaluations. This report covers the period from the effective date of the statute through December 31, 2018. The report only covers projects subject to the provisions of the statute, and reflects the evaluation of solar technologies as expressed in the design development

submissions. It therefore does not include solar installations on schools designed prior to the effective date of the statute, or solar projects undertaken independently of construction or renovation projects.

	Number of Projects with Solar Technologies in Design Development Documents						Total
	2013	2014	2015	2016	2017	2018	
County							
Allegany	N/A	1	N/A	N/A	N/A	N/A	1
Anne Arundel	N/A	N/A	N/A	0	N/A	N/A	0
Baltimore City	N/A	N/A	1	2	0	0	3
Baltimore	0	2	0	1	0	0	3
Calvert	N/A	0	N/A	N/A	N/A	N/A	0
Caroline**	N/A	N/A	N/A	N/A	N/A	0	N/A
Carroll	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cecil	0	0	0	N/A	0	0	0
Charles	N/A	N/A	N/A	0	0	0	0
Dorchester**	N/A	N/A	1	N/A	N/A	N/A	1
Frederick***	N/A	1	2	N/A	0	0	3
Garrett	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Harford*	N/A	1	N/A	N/A	N/A	N/A	1
Howard	0	1	0	N/A	N/A	N/A	1
Kent**	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Montgomery*	0	0	0	0	0	0	0
Prince George's	0	N/A	N/A	N/A	0	0	0
Queen Anne's	N/A	N/A	N/A	N/A	N/A	N/A	N/A
St. Mary's	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Somerset	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Talbot	N/A	N/A	N/A	N/A	0	0	N/A
Washington	0	N/A	N/A	N/A	0	0	0
Wicomico***	N/A	N/A	N/A	1	0	0	1
Worcester	N/A	N/A	N/A	N/A	0	0	N/A
Maryland School for the Blind	0	N/A	N/A	0	N/A	N/A	0

N/A = No major construction projects reviewed

* School system has instituted solar projects independent of construction and renovation projects

** School system has major ground mounted solar photovoltaic installation

*** Solar water heating