STORM DRAINAGE PLAN
WHITTIER BLVD, ROBINWOOD ROAD
KENWOOD PARK
MONTGOMERY CO., MARYLAND.

Scales:- Hor. 1" = 50'
Ver 1" = 5

Mar. 1960

IRWIN I. KAPLAN & ASSOC.
ENGINEERS
SILVER SPRING, MD.

595

SD#D-26,61067-Y

WASHINGTON SUBURBAN SANITARY COMMISSION
* APPROVED MAY 1, 1961
FOR STORM DRAINS ONLY

SUBJECT TO PRIOR INSTALLATION OF WATER & SEWER AND PAVEMENT FOR MOVING ANY W.S.S.C. STRUCTURES AFFECTED.

THE STORM DRAINAGE STRUCTURES SHOWN ON THIS PLAN ARE APPROVED AS TO DESIGN AS A COMPONENT PART OF THE STORM DRAINAGE SYSTEM FOR THIS DRAINAGE AREA. THIS COMMISSION ASSUMES NO RESPONSIBILITY WHATSOEVER FOR ANY DAMAGE WHICH MAY BE CAUSED TO ADJACENT PROPERTY OWNERS OR TO OWNERS DOWNSTREAM, BY REASON OF THE INSTALLATION OF THE DRAINAGE STRUCTURES SHOWN HEREON.

[signature]
CHIEF ENGINEER

THE W.S.S.C. CONSTRUCTION DIVISION SHALL BE NOTIFIED THREE DAYS IN ADVANCE OF BEGINNING CONSTRUCTION.

* Structures 1 through 17 and connecting pipes

All street grades shown hereon given Final Approval by M.N.C.P.&P. Comm. 7/25/60

Approval requested from structure No 1 to and including structure No 17.

30" R.C.C.P. stub, 4.0'±, to connect to storm drainage construction by others

Do not construct cradle closer than 3' to water main on either side

CE487-587-1

SD FILE NO. 595

All storm drains shall be constructed in accordance with the General Specifications of the Wash. Sub. San. Comm. as adopted Sept. 1964 or the latest revision thereof.

Information concerning underground utilities was obtained from available records but the Contractor shall determine the exact location in plan and elevation of the mains by digging test pits by hand at all utility crossings before beginning work under the contract.

Types of structures shown hereon refer to W.S.S.C. Std Storm drainage details unless noted otherwise.

No part of any structure or pipeline shall be constructed on earth fill or unstable subgrade. Construct all official foundation for structures with 1:4:8 concrete and for pipe lines with washed gravel where necessary to provide a firm foundation.

All concrete for structures shall be Wash. Sub. San. Comm's Class "A" Concrete.

Provide steps in channels of structures for pipes larger than 21" dia. in accordance with the details shown on W.S.S.C. Std detail dwg No. 2.12 25-L

If clearances between mains are less than shown on this plan or six (6) inches whichever is less, contact the Storm Drain Section of the Wash. Sub. San. Comm. before proceeding with construction.

Where storm drains pass under water mains notify Mr. James Lee W.S.S.C. System Maintenance Eng'r before excavating in the vicinity of the mains. Backfill shall be made under supervision of W.S.S.C. M.S.O. Dist.

PIPE SCHEDULE		
SIZE	TYPE	LENGTH
15	RCCP	890
18	"	30
21	"	32
24	"	142
27	"	157
30	"	41
33	"	

STRUCTURE SCHEDULE					
No	TYPE	TOP of INLET	FLOW LINE	REMARKS W.S.S.C.	STD
1	B10 INLET	351.27	351.13		
2	B10 INLET	350.20	350.26	"	"
3	B MANHOLE	348.64		"	" 48"D
4	A5 INLET	346.45	345.45	"	"
5	B10 INLET	341.68	340.01	"	"
6	B10 INLET	339.29	339.51	"	"
7	B MANHOLE	338.80		"	" 48"D
8	A5 INLET	338.40	338.62	"	"
9	A5 INLET	335.67	335.70	"	"
10	B10 INLET	350.45	350.68	"	"
11	A5 INLET	337.59	338.02	"	"
12	B10 INLET	338.24	338.42	"	"
13	B10 INLET	332.25	332.41	"	"
14	B5 INLET	332.90	331.97	"	"
15	B10 INLET	333.25	333.51	"	"
16	B MANHOLE	332.10		"	" 48"D
17	B10 INLET	332.86	332.62	"	"

Approval requested from Structure No. 1 to and including Structure No. 17







SD# D-26, 61067-Y

WASHINGTON SUBURBAN SANITARY COMMISSION

* APPROVED MAY 1, 1961

John R. Mayo

* Structures 1 through 17 and connecting pipes.

STORM DRAINAGE PLAN
WHITTIER BLVD. ROBINWOOD ROAD
~~AND HIGHLAND DR.~~
KENWOOD PARK
MONTGOMERY CO. MARYLAND
595
Scale: 1" - 50' Mar. 1960

IRWIN I. KAPLAN & ASSOC
ENGINEERS
SILVER SPRING, MD.

OWNER - A. S. KAY
INDIAN SPRING COUNTRY CLUB
SILVER SPRING, MD.

CE487-587-2

SD FILE NO. 595