

File No. 9245 Continued.

CORRESPONDENCE.

I hope that you may be able to do something whereby an example may be made of Jones as a warning to builders in the future.

Jones is the same man who made so much trouble in South Baltimore, in the matter of Belt street, north of Fort avenue, which you will no doubt recall, we had before us in the Board of Estimates.

Very truly yours,

(Signed) B. T. Pendall,
City Engineer.

File No. 9246.

DEPARTMENT OF PUBLIC IMPROVEMENTS,
SUB-DEPARTMENT OF CITY ENGINEER.

Baltimore, December 10th, 1908.

T. Milton Jones, Esq.,
1520 Light street,
City.

Dear Sir:-

6880

I am advised that you have graded, curbed and paved with cobble stone, Webster street, from Clement to Myson street. Webster street is a public street, and your act of paving the same, with any material, is illegal and contrary to the City's ordinances. Your paving the street with cobble stone is specifically prohibited by the City's ordinance. The curb that you have set has not been set to grade, and the street has been put in generally bad shape through your acts. You have laid sidewalks to the various houses, constructed by you on this street, and no sidewalk is laid with a proper pitch from the building line to the curb. The law requires a pitch not to exceed $1/2$ " to the foot, or $6-1/2$ " for a 13' sidewalk. The smallest pitch which you have given to any sidewalk is 7", and varies from 7" to