

sion has been revoked shall be entitled to be present in person and by counsel on the hearing of the appeal. If a certificate or commission is lost or destroyed a new certificate or commission shall be issued in its place without another examination. A person who has failed to pass the examination for a commission or whose commission has been revoked except for untrustworthiness shall be entitled to apply for a new examination and commission after ninety days from such failure or revocation.

139. On and after June 1, 1939, each boiler used or proposed to be used within this State, except boilers exempt under Section 135, shall be inspected annually internally and externally while not under pressure by the Chief Inspector or by one of the deputy inspectors or special inspectors provided for herein as to its construction, installation, condition and operation. If at any time a hydrostatic test shall be deemed necessary to determine the safety of a boiler, same shall be made, at the direction of the inspector, by the owner or user thereof. Not more than fourteen months shall elapse between internal inspections, and external inspections while under pressure shall also be made at no greater intervals.

If a boiler shall upon inspection be found to be suitable, and to conform to the rules and regulations of the Board of Boiler Rules, the owner or user thereof, shall pay to the Chief Inspector and to be collected by him the sum of one (\$1.00) dollar and the Chief Inspector shall issue to such owner or user an inspection certificate specifying the maximum pressure which the boiler may be allowed to carry. Such inspection certificate shall be valid for not more than fourteen months from its date and it shall be posted under glass in the room containing such boiler or in the case of a portable boiler, in a metal case to be kept in the tool box accompanying the boiler. No inspection certificate issued for a boiler inspected by a special inspector shall be valid after the boiler for which it was issued shall cease to be insured by a duly authorized insurance company. The Chief Inspector or any deputy inspector may at any time suspend an inspection certificate when, in his opinion, the boiler for which it was issued may not continue to be operated without menace to the public safety or when the boiler is found not to comply with the rules herein provided for, and a special inspector shall have corresponding powers with respect to inspection certificates for boilers insured by the company employing him. Such suspension of an inspection certificate shall continue in effect until such boiler shall have been made to conform to the rules and regulations of the Board of Boiler Rules and until said inspection certificate shall have been reinstated.