

*217D. (Location.) Trailer coach parks may be located in any district which is zoned for trailer parks. Each boundary of the park must be at least 200 feet from any permanent residential building located outside the park, unless a majority of the property owners according to area within said 200 feet consent in writing to the establishment of the park.*

*217E. D. (Water Supply.) An adequate supply of pure water for drinking and domestic purposes shall be supplied to meet the requirements of the park. The water supply shall be obtained from the faucets only. No common drinking cups shall be permitted. Each trailer coach space shall be provided with a cold water tap, at least four inches above the ground. An adequate supply of hot water shall be provided at all times in the service buildings for all bathing, washing, cleansing and laundry facilities.*

*217F. (Sanitation Facilities.) Each park shall be provided with toilets, baths or showers, slop sinks and other sanitation facilities which shall conform to the following requirements:*

*(a) The toilet and other sanitation facilities for males and females shall be either in separate buildings or shall be separated, if in the same building, by a soundproof wall.*

*(b) Toilet facilities for males shall consist of not less than one flush toilet for every 15 dependent trailer coaches, one urinal for every 15 dependent trailer coaches, one shower or bath tub with individual dressing accommodations for every 10 dependent trailer coaches, and one lavatory for every 20 dependent trailer coaches.*

*(c) Toilet facilities for females shall consist of not less than one flush toilet for every 10 dependent trailer coaches, one shower or bath tub with individual dressing accommodations for every 10 dependent trailer coaches, and one lavatory for every 20 dependent trailer coaches.*

*(d) Each toilet and each shower or bath tub with individual dressing accommodations, for which provision is made in Sub-sections (b), (c) and (d), shall be in a private compartment.*

*(e) Service buildings housing the toilet facilities shall be permanent structures complying with all applicable ordinances and statutes regulating buildings, electrical installations and plumbing and sanitation systems, and shall be located not closer than 10 feet nor farther than 200 feet from any trailer coach space.*

*(f) The service buildings shall be well lighted at all times of the day and night, shall be well ventilated with screened openings, shall be constructed of such moisture proof material, including painted woodwork, as shall permit repeated cleaning and washing, and shall be maintained at a temperature of at least 68 degrees Fahrenheit during the period from October 1st to May 1st. The floors of the service buildings shall be of water impervious material.*

*(g) 217E. All service buildings and the grounds of the park shall be maintained in a clean, sightly condition and kept free of any condition that will menace the health of any occupant or the public or constitute a nuisance.*