

as near as practical to the floor furnace location, but preferably not in a bedroom. A clear and unobstructed passageway to the floor furnace of at least 30 inches high (to the bottom of joists) by 30 inches wide must be provided from the point of access. The sides and bottom of the passageway shall be lined with concrete or concrete block to extend 4 inches above the ground level and shall connect with the concrete sides of the floor furnace pit (see 4.9.8). The bottom of the passageway may be covered with 2 inches of crushed stone, gravel or similar material in lieu of concrete, if desired. Access to the floor furnace through an opening in the foundation wall will be acceptable where the clearance between the bottom of the floor joists and the general ground level is not less than 36 inches. The access openings in the foundation wall must be at least 24 inches wide and 30 inches high and the entrance protected against snow."

(36) Subsection 4.14.2. Clearance: Delete paragraph (b).

(37) Subsection 4.15.1. Clearance: Delete paragraph (c).

(38) Subsection 4.18. Hot Plates and Laundry Stoves: Delete paragraph (b) as written and renumber present paragraph (c), (b).

(39) Subsection 4.19.2. Clearance for Unlisted Appliances: Delete entire subsection.

(40) Subsection 4.20.3. Clearance for Unlisted Appliances: Delete entire subsection.

(41) Subsection 4.20.4. Mounting of Unlisted Appliances: Delete entire subsection.

(42) Subsection 4.21.3. Clearance for Unlisted Appliances: Delete the entire subsection.

(43) Subsection 4.21.4. Mounting of Unlisted Appliances: Delete this entire subsection.

(44) Subsection 4.22.1. Independent Gas Piping: Change the title to "Gas Piping" by deleting the word "Independent", delete as written and substitute the following: "Gas piping serving a heating appliance may also serve a cooling appliance when the heating and cooling appliance cannot be operated simultaneously."

(45) Subsection 4.22.4. Clearance for Indoor Installation: Delete as written and substitute the following:

(a) Listed air conditioning appliances installed in unconfined spaces shall be installed with clearances not less than specified in Line 1 of Table 11 except as provided in 4.22.4 (a) 1, 2 and 3.

1. Air conditioning appliances listed for installation at lesser clearances than specified in Table 11 may be installed in accordance with their listing and the manufacturer's instructions.

2. Air conditioning appliances listed for installation at greater clearances than specified in Table 11 shall be installed in accordance with their listing and the manufacturer's instructions unless protected as specified in 4.22.4 (a) 3. However, when clearances are specified to provide access for service, they shall not be reduced.

3. Air conditioning appliances installed in unconfined spaces (see 3.4.3a) may be installed with reduced clearances to combustible material provided the combustible material is protected as described in Table 12.