

(b) Air conditioning appliances installed in confined spaces must be installed in accordance with their listing and when such units are installed in spaces such as alcoves and closets, they must be specifically listed for such installations.

When the plenum for an air conditioner which includes provisions for heating air is adjacent to combustible material, the clearance shall be measured to the surface of the plaster or other noncombustible finish when the clearance specified is 2 inches or less.

The clearance to these appliances shall not interfere with the requirements for combustion air, draft hood clearance and relief, and accessibility for servicing. (See 3.3.1 and 3.4)

(46) Subsection 4.23.1. Clearances: Delete all except first paragraph.

(47) Subsection 5.1.1. Appliances, Required to be Vented. Delete 5.1.1 (j) as written and substitute the following: "(j) Appliances listed as vented or unvented will require special approval by the Administrative Authority to be installed unvented."

(48) Subsection 5.4.5. Gas Vents Serving Two or More Gas Appliances Having Draft Hoods: Delete paragraph (c) as written and substitute the following: "(c) The effective area of the manifold, all junction fittings and the common vent connector shall be equal to the combined areas of the draft hood outlets for which it acts as a common carrier or shall be in accordance with approved engineering methods."

(49) Subsection 5.4.6. Marking: Delete entire subsection.

(50) Subsection 5.6.6. Marking: Delete entire subsection.

(51) Subsection 5.7.1. Materials: Delete as written and substitute the following: "Outside gas vents and chimneys shall possess high insulation qualities or be adequately insulated."

(52) Subsection 5.7.2. Condensate Drain. Delete as written and substitute the following: "Provisions shall be made to drain off the condensate."

(53) Subsection 5.9.3. Ventilating Hoods and Exhaust Systems: Add new (c) as follows: "(c) When a fire extinguisher system is provided in the ventilating hood which interrupts the gas supply, a manually reset device must be installed in the interruptor system with appropriate instructions in regard to relighting the appliance."

(54) Part 7.—Definitions:

Delete garage, residential with definition and substitute following: "GARAGE. A building or room in which self-propelled passenger vehicles are or may be stored or repaired."

Add the definition of "Gas Fitting" as follows: "GAS FITTING. Gas Fitting shall mean the work, beginning at the outlet of the meter, of putting together, installing, connecting, and the maintenance and repair of any piping, fitting, fixtures, or other appliances which are to contain gas for heat, light, or power, including attachments and appurtenances."

Section 2. AND BE IT FURTHER ENACTED, That this Ordinance shall take effect forty-five (45) days after it becomes law.