

Table 2.13.2

Observation Time for Various Meter Test Dials To Determine
Whether or Not There is a Gas Leak

Size of Meter Test Dial— Cubic Feet	Observation Time— Minutes
1/2	5
2	10
5	20
10 and larger	30

(10) Subsection 3.1.1. Appliances, Accessories and Equipment to be “Approved”: Delete as written and substitute the following:

All gas appliances and accessories installed for domestic or commercial use shall:

(a) Be listed by a nationally recognized testing agency, or

(b) Comply with applicable American Standard Approval or Listing Requirements covering safe operation, substantial and durable construction and acceptable performance, or

(c) Be acceptable to the governmental authority having jurisdiction.

The word “listed” refers to appliances and accessories which are shown in a list published by an approved nationally recognized testing agency, such as the American Gas Association, Inc. Laboratories and Underwriters Laboratories, Inc., qualified and equipped for experimental testing, and maintaining an adequate periodic inspection of current production of listed models and whose listing states either that the appliance or accessory complies with nationally recognized safety requirements or has been tested and found safe for use in a specified manner. Compliance may also be determined by the presence on the appliance or accessory of a label of such a nationally recognized testing agency, whose label on the appliance or accessory states that it complies with national safety requirements.

In cases where no applicable Standard has been developed for a given class of appliance or accessory, approval of the Administrative Authority should be obtained before the appliance or accessory is installed.

(11) Subsection 3.1.3. Delete entire subsection.

(12) Subsection 3.1.5. Flammable Vapors: Change title to read “Flammable Vapors, Dust or Lint” and delete as written and substitute the following: “Gas appliances shall not be installed in any location where flammable vapors, dust, lint or similar combustible or explosive materials are likely to be present, unless the design, installation and operation are such as to eliminate the possible ignition of such vapors or materials and meets with the Administrative Authority’s approval.

(13) Subsection 3.1.6. Installation in Residential Garages. Delete this entire subsection.

(14) Subsection 3.1.7. Installation in Commercial Garages. Delete the word “commercial” in the title of this subsection and delete paragraphs “(a)” and “(b)” as written and substitute the following: