

(a) Floor mounted heaters in garages for motor vehicles shall be located in a room separated from other parts of the garage by construction having at least a one-hour fire-resistance rating. This room shall not be used for combustible storage and shall have no direct access from the garage storage or repair areas.

All air for combustion purposes entering such a room shall be from outside of the building.

(b) Overhead heaters shall be installed not lower than the height for which they are approved, not less than 8 feet above the floor and protected against physical damage.

(15) Subsection 3.3.1. Accessibility for Service. Delete paragraph (a) as written and substitute the following:

(a) Every gas appliance shall be located with respect to building construction and other equipment so as to permit access to the appliance. Sufficient space (minimum of 24 inches) shall be maintained on sides required to permit cleaning of heating surfaces; the replacement of filters, blowers, motors, burners, controls and vent connections; the lubrication of moving parts where required; and the adjustment and cleaning of burners and pilots. Where appliances are installed in unfinished attics, a floored area at least 3 feet by 3 feet shall be provided at the appliance for servicing and a floored walkway at least 2 feet wide shall be provided between the point of access to the attic and the appliance.

(16) Subsection 3.4.2. Appliances Located in Unconfined Spaces: Renumber present paragraphs (a) and (b), (b) and (c) respectively, and add new paragraph (a) as follows:

(a) To meet the requirements of this section, the space in which the appliances are installed shall be at least sixteen (16) times the total volume of the appliances. When the actual ceiling height of the space is greater than 8' of the volume of the space shall be figured on the basis of a ceiling height of 8'.

(17) Subsection 3.6.1. Connecting Gas Appliances: Delete paragraph (c) and (d) as written and substitute as follows:

(c) Listed appliance connectors on non-portable appliances when the piping outlet is in the same room as the appliance and the connector is adequately protected against physical damage and does not exceed four feet in length.

(d) Aluminum alloy tubing and connectors shall not be used in exterior locations nor in interior locations where they are in contact with masonry, plaster, or are subject to corrosive wettings.

(18) Subsection 3.6.3. Add at end of subsection the following. "This is not required for the installation of a domestic range only when using liquid petroleum gas."

(19) Subsection 4.5.1. Prohibited Installations: Delete last portion of first sentence starting with "or any" and place word "or" before word "bedrooms".

(20) Subsection 4.6.1. Installations in Sleeping Quarters: Delete as written and substitute the following: "Room heaters installed as the only means of heat in rooms used for sleeping or bathing purposes shall be of the sealed combustion chamber type which take their air for combustion from, and discharge the flue gas to, the outside atmosphere."