

“Room heaters installed as means of supplementary heat in rooms used for sleeping or bathing purposes shall be as above or of the vented type. The vented type heater shall be connected to an effective chimney or gas vent and be equipped with an automatic pilot.”

(21) Subsection 4.6.3. Clearance. Delete the second paragraph including the deletion of “(a)” and “(b)”.

(22) Subsection 4.7.2. Clearance: Delete from Table 7, line II and IV pertaining to “Unlisted” and delete footnotes “6” and “9”.

(23) Subsection 4.9.8. Clearance: Delete the last two sentences starting with “When these” and substitute the following: “Where the burner or controls must be serviced from the bottom of the floor furnace, sufficient additional clearance must be provided to permit their removal.”

(24) Subsection 4.9.9. Access: Change title to “Pit to Be Provided”, delete as written and substitute the following: “Where the distance between the floor joists and the ground level is less than 30 inches or the bottom of the floor furnace does not have the required clearances, a pit must be provided under the floor furnace. The access passageway and the bottom of the pit must have a minimum clearance of 30 inches from the bottom of the floor joists. The pit shall be sized to give a clearance of eighteen (18) inches on the control and vent collar sides. If the control and vent collar sides are adjacent to each other, the clearance on the remaining two sides may be reduced to 6 inches. The access passageway (see 4.9.10) must enter the pit at the control side where the 18-inch clearance is provided. The sides and bottom of the pit shall be lined with concrete or concrete block to extend 4 inches above the ground level and shall connect with the concrete sides of the access passageway (see 4.9.10). The bottom of the pit may be covered with 2 inches of crushed stone, gravel, or similar material in lieu of concrete, if desired.”

(25) Subsection 4.9.10. Seepage Pan: Change title to “Access”, delete as written and substitute the following: “Provision shall be made for access to the floor furnace by means of a trap door of at least 24 inches by 24 inches, located at some convenient portion of the house as near as practical to the floor furnace location, but preferably not in a bedroom. A clear and unobstructed passageway to the floor furnace of at least 30 inches high (to the bottom of joists) by 30 inches wide must be provided from the point of access. The sides and bottom of the passageway shall be lined with concrete or concrete block to extend 4 inches above the ground level and shall connect with the concrete sides of the floor furnace pit (see 4.9.9). The bottom of the passageway may be covered with 2 inches of crushed stone, gravel or similar material in lieu of concrete, if desired. Access to the floor furnace through an opening in the foundation wall will be acceptable where the clearance between the bottom of the floor joists and the general ground level is not less than 36 inches. The access openings in the foundation wall must be at least 24 inches wide and 30 inches high and the entrance protected against snow.”

(26) Subsection 4.10.1. Delete paragraph “b”.

(27) Subsection 4.13.3. Delete paragraph “a-3” and “b-4”.

(28) Subsection 4.14.2. Clearance: Delete paragraph (b).

(29) Subsection 4.15.1. Clearance: Delete paragraph (c).