

172.

(A) THE PROVISIONS OF THIS SUBTITLE DO NOT APPLY TO THE FOLLOWING BOILERS AND PRESSURE VESSELS:

(1) BOILERS AND PRESSURE VESSELS UNDER FEDERAL CONTROL OR REGULATION.

(2) PRESSURE VESSELS USED FOR TRANSPORTATION AND STORAGE OF COMPRESSED GASES WHEN CONSTRUCTED IN COMPLIANCE WITH SPECIFICATIONS OF THE U.S. DEPARTMENT OF TRANSPORTATION AND WHEN CHARGED WITH GAS MARKED, MAINTAINED, AND PERIODICALLY REQUALIFIED FOR USE, AS REQUIRED BY APPROPRIATE REGULATIONS OF THE U.S. DEPARTMENT OF TRANSPORTATION.

(3) AIR TANKS LOCATED ON VEHICLES OPERATING UNDER THE RULES OF OTHER STATE AUTHORITIES AND USED FOR CARRYING PASSENGERS OR FREIGHT.

(4) AIR TANKS INSTALLED ON THE RIGHT OF WAY OF RAILROADS AND USED DIRECTLY IN THE OPERATION OF TRAINS.

(5) PRESSURE VESSELS THAT DO NOT EXCEED (A) 5 CU. FT. IN VOLUME AND 250 PSIG PRESSURE; OR (B) 1 1/2 CU. FT. IN VOLUME AND 600 PSIG PRESSURE; OR (C) AN INSIDE DIAMETER OF 6 IN. WITH NO LIMITATION ON PRESSURE.

(6) PRESSURE VESSELS OPERATING AT A WORKING PRESSURE NOT EXCEEDING 15 PSIG.

(7) VESSELS WITH A NOMINAL WATER-CONTAINING CAPACITY OF 120 GAL. OR LESS FOR CONTAINING WATER UNDER PRESSURE, INCLUDING THOSE CONTAINING AIR., THE COMPRESSION OF WHICH SERVES ONLY AS A CUSHION.

(8) HOT WATER SUPPLY BOILERS WHICH ARE DIRECTLY FIRED WITH OIL, GAS OR ELECTRICITY WHEN NONE OF THE FOLLOWING LIMITATIONS ARE EXCEEDED:

(I) HEAT INPUT OF 200,000 BTU/HR.,

(II) WATER TEMPERATURE OF 200F.,

(III) NOMINAL WATER CAPACITY OF 120 GALS. THESE EXEMPT HOT WATER SUPPLY BOILERS SHALL BE EQUIPPED WITH SAFETY RELIEF VALVES.

(B) THE FOLLOWING BOILERS AND PRESSURE VESSELS SHALL BE EXEMPT FROM THE REQUIREMENTS OF SECTIONS 176, 177 AND 178 OF THIS SUBTITLE:

(1) BOILERS OR PRESSURE VESSELS LOCATED ON FARMS AND USED SOLELY FOR AGRICULTURAL PURPOSES.

(2) HEATING BOILERS WHICH ARE LOCATED IN PRIVATE RESIDENCES OR IN APARTMENT HOUSES OF LESS THAN SIX (6) FAMILY UNITS.