

COUNTY LOCAL LAWS

(25) Strike all of Subsection 618.41 and insert new Subsection 618.41 in lieu thereof, to stand in the place of the subsection so stricken, and to read as follows:

"SUBSECTION 618.41 MINIMUM DIMENSIONS: THE HEIGHT OF RISERS AND WIDTH OF TREADS IN INCHES SHALL BE AS FOLLOWS:

USE GROUP	MAXIMUM RISER	MINIMUM TREAD
ONE-AND TWO-FAMILY DWELLINGS (USE GROUP L-3)		
ALL STAIRS WITH CLOSED RISERS	8 1/4"	9" PLUS 1-1/4" NOSING
BASEMENT SERVICE STAIRS WITH OPEN RISERS	8 1/4"	9" PLUS 1/2" NOSING
ALL OTHER RESIDENTIAL (USE GROUPS L-1 AND L-2).....	8"	9" PLUS 1-1/4" NOSING
ASSEMBLY AND INSTITUTIONAL	7-1/2"	9-1/2" PLUS NOSING
BUSINESS	7-3/4"	9-1/2" PLUS NOSING
ALL STAIRWAYS SHALL HAVE UNIFORM RISERS AND UNIFORM TREADS."		