

## COUNTY LOCAL LAWS

ARUNDEL COUNTY, MARYLAND. THE PROVISIONS OF THIS SUBTITLE SHALL APPLY TO ALL PLUMBING, AND PRIVATE AND SEMI-PRIVATE SEWERAGE SYSTEM CONSTRUCTION IN ANY STRUCTURE OR UPON ANY PUBLIC OR PRIVATE PROPERTY WITHIN THE COUNTY.

## SECTION 12-1101

THE PROVISIONS OF THIS SUBTITLE SHALL BE ADMINISTERED AND ENFORCED BY THE DEPARTMENT OF INSPECTIONS AND PERMITS AND THE DIRECTOR THEREOF, HEREINAFTER RESPECTIVELY REFERRED TO AS THE "DEPARTMENT", AND THE "DIRECTOR".

## SECTION 12-1102

IN REFERRING TO UTILITY CONTRACTORS, THIS SUBTITLE PERTAINS ONLY TO THAT PORTION OF UTILITY CONTRACTING WHICH IS DEFINED AS ENGAGING IN THE BUSINESS OF INSTALLING SEPTIC TANKS, DRYWELLS, DRAIN FIELD SYSTEMS AND SEMI-PUBLIC PACKAGE SEWAGE DISPOSAL SYSTEMS.

## SECTION 12-1103

(A) IN SECTION 102, STRIKE THE DEFINITION FOR "HOT WATER" IMMEDIATELY FOLLOWING THE DEFINITION OF "HORIZONTAL PIPE", AND INSERT A NEW DEFINITION IN LIEU THEREOF, TO STAND IN THE PLACE OF THE DEFINITION SO STRICKEN, AND TO READ AS FOLLOWS:

"HOT WATER - WATER SUPPLIED TO PLUMBING FIXTURES AT A TEMPERATURE OF NOT LESS THAN ONE HUNDRED TWENTY DEGREES (120°) FAHRENHEIT, AND NOT MORE THAN ONE HUNDRED FORTY DEGREES (140°) FAHRENHEIT; EXCEPT THAT COMMERCIAL DISHWASHING MACHINES AND SIMILAR EQUIPMENT SHALL BE PROVIDED WITH WATER OF NOT LESS THAN ONE HUNDRED EIGHTY DEGREES (180°) FAHRENHEIT."

(B) SECTIONS 303.1, 304.1.2, 304.1.3, 304.2.1, 304.3.1, 404, 600.4.1.1, 708.4, 717.1, 717.2, 717.3, 804, 805, 901.1, 1100.3, 1100.7.2, 1002, 1002.10, 1003.1.7, 1004.11.8, 1201.1, 1204.4, 1205.1, 1206, 1207.4, 1209.1, 1211.1, 1600.2B, 1600.2C, 1600.2D, 1600.3.1, 1600.3.3, 1600.5.1, 1600.8.3, 1600.8.4, 1600.9C, 1600.9E, 1600.9F, 1600.11, 1800.1C AND 1800.2C OF THE SEVENTH DRAFT OF THE PROPOSED REVISION OF THE STATE PLUMBING CODE BE, AND THEY ARE HEREBY STRICKEN, AND NEW SECTIONS 304.1.2, 304.1.3, 304.2.1, 304.3.1, 404, 600.4.1.1, 708.4, 717.1, 717.2, 717.3,