

ANNE ARUNDEL COUNTY

(2) "SECTION 304.1.2 WATER SUPPLY SYSTEM MATERIALS

WATER SERVICE PIPING SHALL BE MADE OF ASBESTOS CEMENT PIPE, BRASS PIPE, OR COPPER PIPE, LEAD PIPE, CAST IRON WATER PIPE, GALVANIZED WROUGHT IRON PIPE, GALVANIZED OPEN-HEARTH IRON PIPE, OR GALVANIZED STEEL PIPE, OR PLASTIC PIPE WHICH SHALL BE OF POLYETHYLENE PE-TYPE III, 3406, AS DEFINED BY ASTM 1248-68, 160 LB. WORKING PRESSURE AND SHALL CONFORM TO THE COMMERCIAL STANDARD CS 255-63. COPPER TUBE WHEN USED UNDERGROUND SHALL NOT BE LESS THAN TYPE L WHERE A PUBLIC WATER SUPPLY IS USED AND NOT LESS THAN TYPE K WHERE A PRIVATE WATER SUPPLY IS USED. ALL THREADED FERROUS PIPE AND FITTINGS SHALL BE GALVANIZED OR CEMENT LINED. WHEN USED UNDERGROUND IN CORROSIVE SOIL OR FILL, ALL FERROUS PIPE AND FITTINGS SHALL BE COAL-TAR ENAMEL COATED AND THREADED JOINTS SHALL BE COATED AND WRAPPED WHEN INSTALLED."

(3) "SECTION 304.1.3 WATER DISTRIBUTION SYSTEM PIPE

THE WATER DISTRIBUTION SYSTEM SHALL BE OF BRASS, OR COPPER PIPE, COPPER TUBE, GALVANIZED WROUGHT IRON PIPE, GALVANIZED OPEN-HEARTH IRON PIPE, GALVANIZED STEEL PIPE, OR TI-CHROME STAINLESS STEEL, OR LEAD PIPE. COPPER TUBE USED UNDERGROUND SHALL HAVE A WEIGHT OF NOT LESS THAN COPPER WATER TUBE TYPE L AND ABOVE GROUND SHALL HAVE A WEIGHT OF NOT LESS THAN COPPER WATER TUBE TYPE M WHERE PUBLIC WATER SUPPLY IS USED AND TYPE K UNDERGROUND AND TYPE L ABOVEGROUND WHEN A PRIVATE WATER SUPPLY IS USED."

(4) "SECTION 304.2.1 ABOVE-GROUND PIPING WITHIN BUILDINGS

SOIL AND WASTE PIPING ABOVE GROUND IN BUILDINGS SHALL BE OF BRASS PIPE, COPPER PIPE, COPPER TUBE D.W.V. WEIGHT, SERVICE WEIGHT OR HEAVIER CAST IRON SOIL PIPE, GALVANIZED WROUGHT IRON PIPE, GALVANIZED OPEN-HEARTH IRON PIPE, GALVANIZED STEEL PIPE, TI-CHROME STAINLESS STEEL D.W.V. PIPE, OR LEAD PIPE. A.B.S. OR P.V.C., D.W.V. PLASTIC PIPE MAY BE USED IN SINGLE AND TWO (2) FAMILY DWELLING UNITS, OR IN ONE OR TWO STORY BUILDINGS."

(5) "SECTION 304.3.1 ABOVE-GROUND VENTING