

COUNTY LOCAL LAWS

VENT PIPING ABOVE GROUND IN BUILDINGS SHALL BE OF BRASS PIPE, COPPER PIPE, COPPER TUBE, D.W.V. WEIGHT, SERVICE WEIGHT OR HEAVIER CAST IRON SOIL PIPE, GALVANIZED WROUGHT IRON PIPE, GALVANIZED OPEN-HEARTH IRON PIPE, GALVANIZED STEEL PIPE, OR LEAD PIPE. A.B.S. OR P.V.C., D.W.V. PLASTIC PIPE OR TI-CHROME STAINLESS STEEL MAY BE USED IN SINGLE AND TWO (2) FAMILY DWELLING UNITS, OR IN ONE OR TWO STORY BUILDINGS."

(6) "SECTION 404 WATERPROOFING OF OPENINGS

JOINTS AT THE ROOF, AROUND VENT PIPES, SHALL BE MADE WATERTIGHT BY THE USE OF LEAD, COPPER, ALUMINUM, PLASTIC, OR OTHER APPROVED FLASHING OR FLASHING MATERIAL. EXTERIOR WALL OPENINGS SHALL BE MADE WATERTIGHT."

(7) "SECTION 600.4.1.1 WHERE REQUIRED

(A) WHENEVER A FLOOR DRAIN DISCHARGES THROUGH AN OIL INTERCEPTOR, IT MUST FIRST DISCHARGE THROUGH A SAND INTERCEPTOR. MULTIPLE FLOOR DRAINS MAY DISCHARGE INTO ONE (1) SAND INTERCEPTOR WITHOUT INDIVIDUAL FLOOR TRAPS.

(B) WHENEVER THE DISCHARGE OF A FLOOR DRAIN MAY CONTAIN SOLIDS OR SEMI-SOLIDS THAT WOULD BE HARMFUL TO A DRAINAGE SYSTEM, OR TEND TO CHOKO THE SYSTEM, THE DISCHARGE MUST BE THROUGH A SAND INTERCEPTOR.

(C) INTERCEPTORS SHALL ALSO BE REQUIRED WHEN THE ADMINISTRATIVE AUTHORITY DEEMS THEM ADVISABLE TO PROTECT THE DRAINAGE SYSTEM."

(8) "SECTION 708.4 SHOWER FLOORS OR RECEPTORS

FLOORS OR RECEPTORS UNDER SHOWER COMPARTMENTS SHALL BE LAID ON OR BE SUPPORTED BY A SMOOTH AND STRUCTURALLY SOUND BASE. FLOORS UNDER SHOWER COMPARTMENTS, OTHER THAN THOSE LAID DIRECTLY ON THE GROUND SURFACE OR WHERE PREFABRICATED RECEPTORS HAVE BEEN PROVIDED, SHALL BE LINED AND MADE WATERTIGHT BY THE PROVISION OF SUITABLE SHOWER PANS OF DURABLE MATERIAL. SUCH PANS SHALL TURN UP ON ALL SIDES AT LEAST TWO INCHES (2") ABOVE THE FINISHED THRESHOLD