

## ANNE ARUNDEL COUNTY

X 4" TEE-WYE, OR TO ABOVE THE CENTER LINE OF A THREE INCH (3") HORIZONTAL DRAIN BY MEANS OF A 3" X 4" WYE SHALL BE ACCEPTABLE; PROVIDED THAT THE FOUR INCH (4") DRAIN SHALL NOT RECEIVE THE DISCHARGE OF ANY STACK AND THAT IT SHALL RECEIVE ONLY THE DISCHARGE OF FIXTURES LOCATED ON THE FLOOR OR WALL IMMEDIATELY ABOVE THE FOUR INCH (4") DRAIN. ALL SUCH FOUR INCH (4") HORIZONTAL DRAIN LINES SHALL BE SIZED, GRADED, AND VENTED AS IF THE FOUR INCH (4") DRAIN WERE A THREE INCH (3") HORIZONTAL DRAIN."

(14) "SECTION 1100.7.2 OFFSETS OF MORE THAN 45 DEGREES

A STACK WITH AN OFFSET OF MORE THAN FORTY-FIVE DEGREES (45°) FROM THE VERTICAL SHALL BE SIZED AS FOLLOWS:

THE PORTION OF THE STACK ABOVE THE OFFSET SHALL BE SIZED AS FOR A REGULAR STACK BASED ON THE TOTAL NUMBER OF FIXTURE UNITS ABOVE THE OFFSET.

THE OFFSET SHALL BE SIZED AS FOR A BUILDING DRAIN. (TABLE 1100.2A)

THE PORTION OF THE STACK BELOW THE OFFSET SHALL BE SIZED AS FOR THE OFFSET OR BASED ON THE TOTAL NUMBER OF FIXTURE UNITS ON THE ENTIRE STACK WHICHEVER IS THE LARGER. (SEE TABLE 1100.2B COLUMN 4).

A RELIEF VENT FOR THE OFFSET SHALL BE INSTALLED AS PROVIDED IN CHAPTER 12 AND IN NO CASE SHALL A HORIZONTAL BRANCH CONNECT TO THE STACK WITHIN TWO FEET (2') ABOVE OR BELOW THE OFFSET.

FIXTURE BRANCHES MAY BE INSTALLED IN THE HORIZONTAL SECTION BETWEEN OFFSETS PROVIDED NO CONNECTIONS ARE MADE UPSTREAM AND DOWNSTREAM OF OFFSETS.