

COUNTY LOCAL LAWS

(2") LOOP VENT, CIRCUIT VENT, OR TO THE RELIEF VENT USED WITH A LOOP OR CIRCUIT VENT; AND IN CASE OF FOUR (4) FIXTURE UNITS TO A THREE INCH (3") LOOP VENT, CIRCUIT VENT OR TO THE RELIEF VENT USED WITH A LOOP OR CIRCUIT VENT, IF:

(1) NO OTHER FIXTURE IS DRAINED TO THE VENT PIPE, AND

(2) WHERE THE VENT PIPE IS A LOOP, CIRCUIT, OR RELIEF VENT, THE FIXTURE WHICH IS CONNECTED TO THE VENT PIPE IS IN THE SAME STORY AS THE FIXTURES WHICH ARE SERVED BY THE VENT PIPE."

(23) "SECTION 1209.1 BATTERY VENTING

A UNIFORMLY SIZED HORIZONTAL SOIL OR WASTE BRANCH TO WHICH ONE (1) BUT NOT MORE THAN A COMBINATION OF EIGHT (8) FLOOR OUTLET WATER CLOSETS (EXCEPT BLOWOUT TYPE), STALL OR PEDESTAL URINALS, FIXTURES HAVING FLOOR CUTLET TRAP STANDARDS, SHOWERS, BATHTUBS, OR FLOOR DRAINS WHICH ARE CONNECTED IN BATTERY, SHALL BE VENTED BY A CIRCUIT OR LOOP VENT WHICH SHALL TAKE OFF IN FRONT OF THE LAST FIXTURE CONNECTION, DOWNSTREAM FROM THE FIXTURE NEAREST THE STACK. IN ADDITION, LOWER FLOOR BRANCHES SERVING MORE THAN THREE (3) WATER CLOSETS SHALL BE PROVIDED WITH A RELIEF VENT TAKEN OFF IN FRONT OF THE FIRST FIXTURE CONNECTION, DOWNSTREAM FROM THE FIXTURE NEAREST THE STACK. WHEN LAVATORIES OR SIMILAR FIXTURES DISCHARGE INTO SUCH BRANCHES, EACH VERTICAL BRANCH SERVING SUCH FIXTURES SHALL BE PROVIDED WITH A CONTINUOUS VENT OR IN ACCORDANCE WITH THE PROVISIONS OF PARAGRAPH 1207.4."

(24) "SECTION 1211.1 DISTANCE OF TRAP FROM VENT

EACH FIXTURE TRAP SHALL HAVE A PROTECTING VENT SO LOCATED THAT THE DEVELOPED LENGTH OF THE FIXTURE DRAIN FROM THE TRAP WEIR TO THE VENT FITTING IS IN ACCORDANCE WITH THE REQUIREMENTS SET FORTH IN TABLE 1211.1.

TABLE 1211-1

MAXIMUM DISTANCE OF FIXTURE TRAP FROM VENT

<u>SIZE OF FIXTURE DRAIN INCHES</u>	<u>DISTANCE - TRAP TO VENT</u>
1 - 1 1/2	3 FT. 6 IN.