

ANNE ARUNDEL COUNTY

2	5 FT.
3	6 FT.
4	10 FT.

NOTE: THE DEVELOPED LENGTH BETWEEN THE TRAP OF A WATER CLOSET (MEASURED FROM TOP OF FLOOR FLANGE TO INNER EDGE OF THE VENT) AND ITS VENT SHALL NOT EXCEED SIX FEET (6')."

(25) "SECTION 1600.2

(B) APPLICATIONS FOR SAID PERMIT SHALL BE IN A FORM REQUIRED BY THE APPROVING AUTHORITY AND SHALL INCLUDE COMPLETE PLANS AND SPECIFICATIONS FOR THE DESIRED INSTALLATION(S). THE APPROVING AUTHORITY SHALL REQUIRE A SOIL EVALUATION INCLUDING PERCOLATION AND OTHER PERTINENT TESTS, SAID EVALUATION TO BE CONDUCTED UNDER ITS SUPERVISION, WITH SUCH INFORMATION TO BE MADE PART OF THE APPLICATION. WHEN THERE IS EVIDENCE THAT A GEOGRAPHICAL FORMATION HAS A HIGH AND FLUCTUATING WATER TABLE DURING SPECIFIED MONTHS OF THE YEAR, THE APPROVING AUTHORITY MAY INDICATE THE TIMES DURING WHICH THE TESTS ARE TO BE MADE."

(26) "SECTION 1600.2

(C) PERCOLATION TESTS SHALL BE CONSIDERED INVALID AFTER ONE (1) YEAR FROM THE DATE OF TESTING AND SHALL BE MADE IN SUFFICIENT NUMBER AND AT SUCH LOCATIONS AS SPECIFIED BY THE APPROVING AUTHORITY TO ASSURE A RELIABLE DETERMINATION OF SUB-SURFACE CONDITIONS. THE PERCOLATION DRAWDOWN RATE MAY RANGE BETWEEN 0 AND 30 MINUTES. THE RESULTS OF PERCOLATION TESTS SHALL BE CONSIDERED IN CONJUNCTION WITH AVAILABLE INFORMATION ON TOPOGRAPHY, SOIL TYPE AND CONDITION, SURFACE AND SUBSURFACE DRAINAGE CONDITIONS, WATER TABLE LEVEL, AND THE HISTORY OF FAILURE OF SEPTIC SYSTEMS IN SURROUNDING AREAS, AND SOIL MAPS DATA."

(27) "SECTION 1600.2

(D) (I) WHEN, UPON REVIEW OF THE APPLICATION, THE APPROVING AUTHORITY IS SATISFIED THAT THE PROPOSED DESIGN IS ADEQUATE, A WRITTEN PERMIT TO PROCEED WITH CONSTRUCTION SHALL BE ISSUED. THE LENGTH OF TIME A PERMIT IS TO RUN SHALL BE SPECIFIED IN SUCH PERMIT AND SHALL NOT EXCEED ONE (1) YEAR. SAID PERMIT SHALL AUTOMATICALLY BECOME INOPERATIVE AT THE