

## COUNTY LOCAL LAWS

## EXPIRATION OF THE PRESCRIBED PERIOD.

(II) WHEN, UPON REVIEW OF THE APPLICATION, THE APPROVING AUTHORITY IS CONVINCED THAT THE PROPOSED DESIGN IS INADEQUATE, OR SOIL AND GEOLOGICAL CONDITIONS ARE SUCH AS TO PRECLUDE SAFE AND PROPER OPERATIONS OF THE DESIRED INSTALLATION(S), A PERMIT TO PROCEED WITH CONSTRUCTION SHALL BE DENIED."

## (28) "SECTION 1600.3.1 DESIGN

THE DESIGN OF THE INDIVIDUAL SEWAGE DISPOSAL SYSTEM MUST TAKE INTO CONSIDERATION LOCATION WITH RESPECT TO WELLS OR OTHER SOURCES OF WATER SUPPLY, TOPOGRAPHY, WATER TABLE, SOIL CHARACTERISTICS, AREA AVAILABLE, AND MAXIMUM OCCUPANCY OF THE BUILDING AND FACILITIES REQUIRING WATER USAGE."

## (29) "SECTION 1600.3.3 SANITARY SEWAGE

THE SYSTEM SHALL BE DESIGNED TO RECEIVE ALL SANITARY SEWAGE, INCLUDING LAUNDRY WASTE FROM THE BUILDING, AND BACKWASH EFFLUENT FROM SWIMMING POOL WHEN APPROPRIATE. DRAINAGE FROM BASEMENT FLOOR, FOOTING OR ROOFS SHALL NOT ENTER THE SYSTEM."

## (30) "SECTION 1600.5.1

(A) WHEN SUBSURFACE IRRIGATION IS CONTEMPLATED, TEST PIT SHALL BE PREPARED ONE FOOT (1') SQUARE BUT NOT LESS THAN TWO FOOT (2') DEEP. AT THE TIME OF CONDUCTING THE PERCOLATION TEST FOR A DRYWELL, A CLEAN HOLE ONE FOOT (1') SQUARE AND ONE FOOT (1') DEEP SHALL BE PREPARED IN THE BOTTOM OF THE TEST PIT."

## (31) "SECTION 1600.8.3 DEPTH BELOW GRADE

THE TOP SHALL BE NOT MORE THAN TWELVE INCHES (12") BELOW FINISHED GRADE, UNLESS OTHERWISE PERMITTED BY THE APPROVING AUTHORITY."

## (32) "TABLE 1600.8.4 DESIGN OF SEEPAGE PIT COVERS

---

PIT DIAMETER	PIT WALL THICKNESS	COVER THICK- NESS	COVER WGT. (LBS.)	REINFORCING STEEL REQUIRED IN TWO PERPENDICULAR DIRECTIONS
-----------------	-----------------------	-------------------------	-------------------------	---