

ANNE ARUNDEL COUNTY

5 FT.	6"	5"	1230	#5 @ 10 1/2"
6 FT.	8"	5"	1770	#5 @ 9"
8 FT.	8"	6"	3780	#5 @ 7 1/2" C/C
10 FT.	8"	8"	7850	#5 @ 6 1/2" C/C "

(33) "SECTION 1600.9

(C) THE MINIMUM SIZE PIPE SHALL BE FOUR INCHES (4") AND THE MINIMUM SPACING REQUIREMENTS FOR DISPOSAL FIELDS SHALL CONFORM TO THOSE SET FORTH IN TABLE 1600.9D."

(34) "SECTION 1600.9

(E) DISPOSAL LINES SHALL BE CONSTRUCTED OF NOT LESS THAN FOUR INCH (4") PIPE OF OPEN JOINTED OR HORIZONTALLY SPLIT OR PERFORATED CLAY TILE, PERFORATED ASBESTOS CEMENT, PERFORATED BITUMINIZED FIBER OR PLASTIC PIPE OR OPEN JOINTED CAST IRON SOIL PIPE. IF CLAY TILE OR OPEN JOINTED CAST IRON SOIL PIPE IS USED, THE SECTIONS SHALL BE SPACED NOT MORE THAN ONE HALF INCH (1/2") APART, AND THE UPPER HALF OF THE JOINT SHALL BE PROTECTED BY ASPHALT-TREATED PAPER WHILE THE PIPING IS BEING COVERED."

(35) "SECTION 1600.9

(F) THE TRENCH BOTTOM SHALL BE UNIFORMLY GRADED TO SLOPE FROM A MINIMUM OF ONE INCH (1") TO A MAXIMUM OF FOUR INCHES (4") PER ONE HUNDRED FEET (100')."

(36) "SECTION 1600.11 PIPING MATERIAL

ALL PIPING FROM BUILDING DRAIN TO THE DISTRIBUTION BOX SHALL BE FOUR INCHES (4") OR LARGER UNCOATED SERVICE OR HEAVIER WEIGHT BELL AND SPIGOT CAST IRON. CAST IRON PIPE MUST ALSO BE USED FROM THE EDGE OF A DRYWELL TO SOLID GROUND."

(37) "SECTION 1800.1

(C) NO PIPING ARRANGEMENTS WILL BE