

METAL RECEPTACLE SHALL BE PROVIDED FOR OILY WASTE. SMOKING IN OR ABOUT ANY SURFACE STRUCTURE IS RESTRICTED TO A PLACE WHERE IT WILL NOT CAUSE A FIRE OR EXPLOSION.

REVISOR'S NOTE: This subsection presently appears as Article 66C, section 614(a) of the Code. The only changes made are in style.

(B) GASOLINE ENGINES.--IF A GASOLINE ENGINE IS USED TO PROPEL ANY VENTILATING FAN, THE FUEL TANK MAY NOT BE PLACED IMMEDIATELY ABOVE THE ENGINE. THE FUEL TANK SHALL BE PLACED OUTSIDE THE FANHOUSE AND MAY BE PLACED IN A POSITION TO ALLOW GRAVITY FEED.

REVISOR'S NOTE: This subsection presently appears as Article 66C, section 614(b) of the Code. The only changes made are in style.

(C) FIRE DOORS.--UNLESS ANY EXISTING STRUCTURE LOCATED WITHIN 100 FEET OF ANY INTAKE MINE OPENING IS OF REASONABLY FIREPROOF CONSTRUCTION, FIRE DOORS SHALL BE ERECTED AT EFFECTIVE POINTS IN THE MINE OPENINGS TO PREVENT SMOKE OR FIRE FROM OUTSIDE SOURCES FROM ENDANGERING MEN WORKING UNDERGROUND. THESE DOORS SHALL BE TESTED AT LEAST MONTHLY TO ASSURE EFFECTIVE OPERATION.

REVISOR'S NOTE: This subsection presently appears as Article 66C, section 614(c) of the Code. The only changes made are in style.

#### 7-447. FIRE PREVENTION AND CONTROL.

(A) FIRE-FIGHTING EQUIPMENT.--EACH MINE SHALL BE PROVIDED WITH SUITABLE FIRE-FIGHTING EQUIPMENT SUCH AS SUPPLIES OF ROCK-DUST AT DOORS AND OTHER STRATEGIC PLACES, WATER LINES AND HOSE, WATER OR CHEMICAL TRUCKS, AND FIRE EXTINGUISHERS. THE BUREAU SHALL PRESCRIBE THE ADEQUATE SIZE OF THE EQUIPMENT FOR THE MINE.

REVISOR'S NOTE: This subsection presently appears as Article 66C, section 615(a) of the Code. The only changes made are in style.

(E) EXTINGUISHERS.--CLEAN DRY SAND, ROCK-DUST, OR FIRE EXTINGUISHERS SUITABLE FROM A TOXIC AND SHOCK STANDPOINT, SHALL BE PROVIDED AND PLACED AT EACH ELECTRICAL STATION, SUBSTATION, TRANSFORMER STATION, AND PERMANENT PUMP STATION OUT OF THE AREA OF SMOKE IN