

## ANNE ARUNDEL COUNTY

PIPING IN THE GROUND SHALL BE LAID ON A FIRM BED FOR ITS ENTIRE LENGTH, EXCEPT WHERE SUPPORT IS OTHERWISE PROVIDED WHICH IS ADEQUATE IN THE JUDGMENT OF THE ADMINISTRATIVE AUTHORITY.

(21) SECTION 900.1A INDIRECT WASTES REQUIRED

WASTES FROM THE FOLLOWING FIXTURES, DEVICES, APPLIANCES, OR APPARATUS SHALL DISCHARGE TO THE BUILDING DRAINAGE SYSTEM THROUGH AN INDIRECT WASTES, MEETING THE MATERIAL AND DRAINAGE PIPE SIZING REQUIREMENTS OF THIS CODE.

(22) SECTION 1002 DESIGN OF BUILDING WATER DISTRIBUTION SYSTEM

WATER PIPING SYSTEMS SHALL BE DESIGNED AND INSTALLED SO THAT THE MAXIMUM VELOCITY AT ANY TIME SHALL NOT EXCEED THE LESSER OF EIGHT FEET (8') PER SECOND, OR TO THE MAXIMUM LIMIT RECOMMENDED BY THE MANUFACTURER OR AN INDUSTRY STANDARDS.

(23) SECTION 1003.1.7 WATER HEATING EQUIPMENT VALVE

THE COLD WATER BRANCH TO EACH HOT WATER STORAGE TANK OR WATER HEATER SHALL BE PROVIDED WITH A VALVE LOCATED NEAR THE EQUIPMENT, WHICH VALVE SHALL ONLY SERVE SAID EQUIPMENT. EACH TANK OR HEATER SHALL BE EQUIPPED WITH AN APPROVED AUTOMATIC RELIEF VALVE AS SPECIFIED IN PARAGRAPH 1005.2.

(24) SECTION 1004.11.8 LAWN SPRINKLERS

LAWN SPRINKLER SYSTEMS WHEN CONNECTED TO A POTABLE WATER SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE PROVISIONS OF THIS SUBTITLE. ADEQUATE AND PROPER PROVISION SHALL BE MADE FOR CONTROL AND DRAINAGE, AND TO PREVENT BACKSIPHONAGE. THE WATER SUPPLY LINES MAY BE LAID AT A DEPTH LESS THAN THREE AND ONE-HALF FEET (3 1/2').

(25) SECTION 1100.3 MINIMUM SIZE OF SOIL AND WASTE STACKS

NO SOIL OR WASTE STACK SHALL BE SMALLER THAN THE LARGEST HORIZONTAL BRANCH CONNECTED THERETO, EXCEPT THAT:

(A) A 4" X 3" WATER CLOSET CONNECTION SHALL NOT BE CONSIDERED AS A REDUCTION IN PIPE SIZE.

(B) A FOUR INCH (4") HORIZONTAL DRAIN TO A THREE INCH (3") SOIL STACK BY MEANS OF A 3" X 4" TEE-WYE, OR TO ABOVE THE CENTER LINE OF A THREE INCH (3")