

ANNE ARUNDEL COUNTY

WITH THE DRAIN FROM A BACK-VENTED LAVATORY SERVING AS A WET VENT FOR A BATHTUB OR SHOWER STALL AND FOR THE WATER CLOSET, PROVIDED THAT:

(A) NOT MORE THAN ONE (1) FIXTURE UNIT IS DRAINED INTO A ONE AND ONE-HALF INCH (1 1/2") DIAMETER WET VENT OR MORE THAN FOUR (4) FIXTURE UNITS DRAIN INTO A TWO INCH (2") DIAMETER WET VENT.

(B) THE HORIZONTAL BRANCH SHALL BE A MINIMUM OF TWO INCHES (2") AND CONNECT TO THE STACK AT THE SAME LEVEL AS THE WATER CLOSET DRAIN OR BELOW THE WATER CLOSET DRAIN WHEN INSTALLED ON THE TOP FLOOR. SAID BRANCH MAY ALSO CONNECT TO THE WATER CLOSET BEND.

(30) SECTION 1206 STACK VENTING

1206.1 FIXTURE GROUPS

A SINGLE BATHROOM GROUP OF FIXTURES CONSISTING OF A WATER CLOSET, BASIN, SHOWER OR TUB AND A KITCHEN SINK (WITH DISPOSAL AND DISHWASHER) LOCATED BACK-TO-BACK TO THE BATHROOM, OR TWO (2) BATHROOMS BACK-TO-BACK, EACH CONSISTING OF ONE (1) TOILET, BASIN, SHOWER OR TUB MAY BE INSTALLED WITHOUT INDIVIDUAL FIXTURE VENTS IN A ONE-STORY BUILDING OR ON THE TOP FLOOR OF A BUILDING PROVIDED EACH FIXTURE DRAIN CONNECTS INDEPENDENTLY TO THE STACK AND IN ACCORDANCE WITH THE REQUIREMENTS IN TABLE 1211.1. A SIDE INLET CONNECTION INTO A FULL FOUR INCH (4") CLOSET BEND SHALL BE CONSIDERED TO BE AN INDEPENDENT CONNECTION TO THE STACK.

1206.2 LOWER FLOORS

LOWER FLOORS MAY BE VENTED AS SET FORTH IN PARAGRAPH 1206.1, PROVIDED THAT (I) A SEPARATE WYE AND UPRIGHT ONE-EIGHTH (1/8) BEND IS INSTALLED IN THE STACK, (II) THE STACK GROUP IS INSTALLED ABOVE THE ONE-EIGHTH (1/8) BEND, AND (III) A TWO INCH (2") VENT IS INSTALLED NOT LESS THAN SIX INCHES (6") ABOVE THE FLOOD LINE OF THE TOP FIXTURE.

(31) SECTION 1207.4 LOOP VENTS

A FIXTURE OTHER THAN A KITCHEN SINK OR DISPOSAL HAVING A HYDRAULIC LOAD OF NOT MORE THAN TWO (2) FIXTURE UNITS MAY BE CONNECTED TO A TWO INCH (2") LOOP VENT, CIRCUIT VENT, OR TO THE RELIEF VENT USED WITH A LOOP OR CIRCUIT VENT; AND IN CASE OF FOUR (4) FIXTURE UNITS TO A THREE INCH (3") LOOP VENT, CIRCUIT VENT OR TO THE RELIEF VENT USED WITH A LOOP OR CIRCUIT VENT, IF:

(1) NO OTHER FIXTURE IS DRAINED TO THE VENT PIPE, AND