

COUNTY LOCAL LAWS

NOT BE OVER-TIGHTENED; SAID JOINTS MAY BE TIGHTENED ONE-HALF (1/2) TO ONE (1) FULL TURN WITH A STRAP WRENCH AFTER HAND TIGHTENING.

(B) JOINTS MAY BE MADE BY CAULKING WITH LEAD AND OAKUM, OR BY USE OF A COMPRESSION GASKET THAT IS COMPRESSED WHEN THE PLASTIC PIPE IS INSERTED INTO THE CAST IRON HUB END OF THE PIPE. NO ADAPTERS ARE REQUIRED FOR THIS CONNECTION.

(C) TWO (2) PIPES WITH THE SAME OUTSIDE DIAMETER MAY BE JOINED WITH AN APPROVED ELASTOMERIC SEALING SLEEVE AND STAINLESS STEEL CLAMP, CLAMPING SCREW AND HOUSING.

(3) SECTION 401.9 PLASTIC PIPE TO METAL PIPE

A COMPRESSION TYPE FITTING SHALL BE USED TO CONNECT PLASTIC PIPE TO METAL PIPE.

(4) SECTION 407 VICTAULIC PIPE, COUPLINGS AND FITTINGS

VICTAULIC COUPLINGS, STYLE 77 AND 75, AND VICTAULIC "FULL FLOW" FITTINGS MAY BE USED IN SINGLE AND MULTI-STORY BUILDING STRUCTURES FOR ROOF AND/OR STORM DRAINS, CHILLED AND CONDENSATE WATER PIPING IN AIR CONDITIONING SYSTEMS, DRAIN, WASTE AND VENT SYSTEMS, AND HOT AND COLD WATER DOMESTIC SYSTEMS.

(5) SECTION 806 STRAINS AND STRESSES

806.1 INSTALLATION OF PIPE

PIPING IN A PLUMBING SYSTEM SHALL BE SO INSTALLED AS TO PREVENT UNDUE STRAINS AND STRESSES.

806.2 EXPANSION AND CONTRACTION

PROVISION SHALL BE MADE FOR EXPANSION OF PIPING AND FOR STRUCTURAL SETTLEMENT THAT MAY AFFECT THE PIPING.

(6) SECTION 901.1

(B) ACID WASTE

ACID AND CHEMICAL WATER PIPES, VENT PIPES, AND FITTINGS SHALL BE OF MATERIALS UNAFFECTED BY THE DISCHARGE OF SUCH WASTES.

(7) SECTION 1600.8.1

(G) SEEPAGE PITS SHALL BE NO CLOSER THAN THREE (3) TIMES THE DIAMETER OF THE LARGEST PIT AS MEASURED FROM SIDE TO SIDE.