

COUNTY LOCAL LAWS

shall be subject to a fine of not more than One Hundred Dollars (\$100.00) for such violation, and an additional fine of Twenty-five Dollars (\$25.00) for each day that such violation continues commencing on the first day after the expiration of the time so fixed by the Administrative Authority to correct such condition.

23-37 Repeal

That all Acts and parts of Acts, whether local or general, inconsistent with the provisions of this Act are hereby repealed to the extent of such inconsistency, except that nothing herein contained shall be construed to affect any of the provisions of Chapter 539 of the Acts of 1924, or any amendments thereto.

SECTION 2. BE IT FURTHER ENACTED BY THE COUNTY COUNCIL OF BALTIMORE COUNTY, MARYLAND, that the following Sections, Subsections and Tables of the National Standard Plumbing Code as revised June 1971, herein adopted, are hereby repealed and re-enacted with amendments to read as follows:

2.16 Freezing

Water service piping and sewers shall be installed below recorded frost penetration but not less below grade than 3 feet 0 inches for water piping and 2 feet 6 inches for sewers. Water, soil or waste piping are not permitted outside of a building or in an exterior wall unless complete and proper provision is made to protect such pipe from freezing.

2.19 Connection to Water and Sewer System

2.19.1 General

The water distribution and drainage system of any building in which plumbing fixtures are installed shall be connected to a public water supply and sewer system respectively if available. A public water supply system and/or public sewer system shall be deemed available to a premise used for human occupancy if such a premise is within [200] 500 feet, measured along a street, alley, or easement, of the public water supply or sewer system and a connection conforming with the standards set forth in the Code may be made thereto. THESE PREMISES SHALL BE CONNECTED TO THE PUBLIC SYSTEMS REGARDLESS OF THE OPERATING CONDITION OF THEIR PRIVATE INSTALLATIONS.

2.24 Toilet Facilities for Workmen

Suitable toilet facilities shall be provided and maintained in a sanitary condition for the use of workmen