

COUNTY LOCAL LAWS

(B) SUCH REGULATIONS SHALL SET FORTH THE STANDARDS AND REQUIREMENTS FOR THE FOLLOWING ELEMENTS OF FIRE ALARM SYSTEMS WITHIN THE COUNTY:

1. ACCEPTABLE DESIGN FEATURES
2. REQUIREMENTS OF LOCAL FIRE ALARM SYSTEMS
3. FIRE ALARM ZONES
4. SOURCES OF ELECTRIC POWER
5. WIRING REQUIREMENTS, INCLUDING PROVISIONS SAFEGUARDING THE USE OF ELEVATORS
6. SYSTEMS OPERATIONS
7. ANNUNCIATORS
8. CODED SYSTEMS
9. STRIKING STATIONS
10. SUCH OTHER ELEMENTS AS REQUIRED.

(C) ALL APPARATUS, MATERIALS, EQUIPMENT AND SYSTEMS USED IN CONNECTION WITH AN ALARM SYSTEM, EXCEPT THE WIRING THEREOF, TO BE INSTALLED UNDER THE PROVISIONS OF THESE REGULATIONS, SHALL BE DESIGNED AND OF A TYPE SUITABLE FOR THE VOLTAGE AND CURRENT AVAILABLE AND BE SPECIFICALLY APPROVED FOR THE PURPOSE BY THE DEPARTMENT BEFORE INSTALLATION. THEY SHALL BE TESTED AND LISTED BY THE UNDERWRITERS' LABORATORIES, INC., FOR FIRE ALARM SERVICES BEFORE SUBMISSION TO THE DEPARTMENT.

ARTICLE VII
STANDARDS AND REQUIREMENTS FOR
ELECTRICAL INSTALLATIONS

17-38. GENERALLY.

(A) IT SHALL BE UNLAWFUL FOR ANYONE TO SELL OR INSTALL ELECTRICAL EQUIPMENT NOT HAVING THE CERTIFICATION OF AN INSPECTION AUTHORITY APPROVED BY THE DEPARTMENT.

(B) THE STANDARDS AND REQUIREMENTS OF THIS CHAPTER SHALL BE BASED UPON THE CURRENTLY DESIGNATED EDITION OF THE NATIONAL ELECTRICAL CODE AND AMENDMENTS THERETO AS SPECIFIED IN REGULATIONS ADOPTED BY THE COUNTY EXECUTIVE AND APPROVED BY THE COUNTY COUNCIL PURSUANT TO PROCEDURES SET FORTH IN SECTION 17-2(B) AND ARE HEREBY DECLARED TO BE MINIMUM STANDARDS AND REQUIREMENTS. ANY