

(5) Five rings or whistles: Accident in mine -- send stretcher;

(6) Additional signals: The operator and district mine inspector by agreement may add additional signals; however, these signals must be printed together with the code on large posters or cards, and displayed in the engine room and at every point where used.

(d) A person may not deface, pull down, destroy, interfere with, or disregard any notice board, signal, or warning in any mine, knowingly damage any signal or communication system, knowingly give or cause to be given any wrong signal within or about the mine, deface or destroy any general or special rules or mining laws, or knowingly destroy, falsify, remove, or conceal any record or report required to be made and kept.]

[7-428.

Telephone service or equivalent communication facilities shall be provided at the bottom of each main shaft or slope and in the mine from the surface to any working section of the mine where the working is at least 1,500 feet from the surface. A telephone line, other than a cable, shall be carried on insulators, installed on the opposite side from the power or trolley wire. If the service or facility crosses any power or trolley wire, it shall be insulated adequately. Each telephone circuit on the surface shall be protected by lightning arresters.]

[7-429.

An overhead high-potential power line shall be placed at least 15 feet above the ground and 20 feet above a driveway or haulageway. It shall be installed on insulators and supported and guarded to prevent contact with other circuits. An overhead power circuit shall be protected against lightning and voltage surges. A high-potential power line shall be protected adequately by circuit breakers, fuses, or both. Electric wiring in surface buildings shall be installed to prevent minimum fire and contact hazards.]

[7-430.

(a) Unless a surface transformer is isolated by elevation at least 8 feet above the ground, it shall be enclosed in a transformer house or surrounded by a suitable fence at least 6 feet high. If the enclosure is metal, it shall be grounded effectively. The gate or door to the enclosure shall be locked at all times, unless an authorized person is present.

(b) Each surface transformer containing flammable oil and installed where it presents a fire hazard, such as near mine openings or in or near combustible buildings, shall be

---