

(2) MAINTAIN THE SMOKE DETECTOR.

~~(D)(C)~~ (1) AFTER INVESTIGATING A FIRE OF ANY RESIDENTIAL DWELLING PLACE DESCRIBED IN SUBSECTION (A) OF THIS SECTION, THE STATE FIRE MARSHAL OR THE LOCAL INVESTIGATING AUTHORITY SHALL ISSUE TO THE OCCUPANT A SMOKE DETECTION INSTALLATION ORDER IN THE ABSENCE OF REQUIRED SMOKE DETECTORS. FAILURE TO COMPLY WITH SUCH AN ORDER WITH FIFTEEN DAYS OF RE-OCCUPANCY CONSTITUTES A VIOLATION.

(2) NOTWITHSTANDING THE PROVISIONS OF SECTION 13 OF THIS ARTICLE, FAILURE TO COMPLY WITH THE SMOKE DETECTION INSTALLATION ORDER ISSUED UNDER PARAGRAPH I OF THIS SUBSECTION SHALL BE PUNISHABLE ONLY BY A FINE NOT EXCEEDING \$50.

(3) FAILURE TO COMPLY WITH THIS SECTION MAY NOT BE USED AS A POLICY DEFENSE IN THE SETTLEMENT OF A PROPERTY INSURANCE CLAIM.

~~(4)--THESE--PROVISIONS--SHALL--HAVE--NO--EFFECT--UPON EXISTING-PUBLIC-LOCAL-LAW-OR-REGULATIONS-WHICH-REQUIRE-SMOKE DETECTORS-IN-OCCUPANCIES-AS-DESCRIBED-IN-SUBSECTIONS(C)--AND (D)-~~

~~(e)~~ ~~(E)~~(D) Approved smoke detecting devices shall be installed not to exceed the lineal or square footage allowances specified, based on the generally accepted test standards under which they were tested and approved.

~~(d)~~ ~~(F)~~(E) Smoke detection systems, INCLUDING SPECIALIZED SMOKE DETECTORS FOR THE DEAF AND HEARING IMPAIRED, shall be approved for the particular system and shall only be used for detection and signaling in the event of fire.

~~-(e)--Smoke (G)(F) UNLESS PERMITTED UNDER SUBSECTION (E)(B) OF THIS SECTION, SMOKE detection systems shall operate on an AC primary source of electric power. Each detector shall be wired into the circuit serving the area in which it is located.-}~~

[[f]] ~~(E)~~~~(H)~~(G) Smoke detection systems may operate on approved power supplies other than an AC primary source when approved by the Fire Prevention Commission, but only when it is clearly evident that reasonable safety is secured.

[[g]] ~~(F)~~~~(I)~~(H) Sale and installation of smoke detection systems AND SPECIALIZED SMOKE DETECTORS FOR THE DEAF AND HEARING IMPAIRED shall be in accordance with State of Maryland Fire Prevention Code regulations.

[[h]] ~~(G)~~ ~~(J)~~(I) Approval shall be obtained from the State Fire Marshal by every individual, firm or corporation commercially selling, installing, or repairing smoke detection systems. Application for such approval shall be in the manner prescribed by the State Fire Marshal.