

(2) AN EMERGENCY POWER SYSTEM SHALL MEET THE FOLLOWING REQUIREMENTS:

(I) IN THE EVENT OF FAILURE OF THE NORMAL ELECTRIC SERVICE, THE EMERGENCY ELECTRICAL POWER SHALL BE ACTIVATED IMMEDIATELY;

(II) THE EMERGENCY GENERATOR SET SHALL COME TO FULL SPEED AND LOAD ACCEPTANCE WITHIN 10 SECONDS; AND

(III) THE EMERGENCY GENERATOR SHALL HAVE THE CAPABILITY OF 48 HOURS OF OPERATION FROM FUEL STORED ON-SITE.

(3) (I) THE EMERGENCY POWER SYSTEM SHALL BE TESTED ONE TIME EACH MONTH.

(II) THE EMERGENCY POWER SYSTEM TEST SHALL REQUIRE THAT THE GENERATOR BE EXERCISED FOR A MINIMUM OF 30 MINUTES UNDER NORMAL EMERGENCY FACILITY CONNECTED LOAD.

(III) THE TEST SHALL BE RECORDED IN A PERMANENT LOG BOOK MAINTAINED FOR THAT PURPOSE.

(D) THE EMERGENCY POWER SYSTEM SHALL PROVIDE LIGHTING IN THE FOLLOWING AREAS OF THE FACILITY:

(1) AREAS OF EGRESS AND PROTECTION AS REQUIRED BY THE STATE FIRE PREVENTION CODE AND LIFE SAFETY CODE 101 ADOPTED BY THE ~~STATE FIRE MARSHAL'S OFFICE~~ STATE FIRE PREVENTION COMMISSION;

(2) NURSES' STATION;

(3) DRUG DISTRIBUTION STATION OR UNIT DOSE STATION;

(4) AN AREA FOR EMERGENCY TELEPHONE USE;

(5) BOILER OR MECHANICAL ROOM;

(6) KITCHEN;

(7) EMERGENCY GENERATOR LOCATION AND SWITCH GEAR LOCATION;

(8) ELEVATOR, IF OPERABLE ON EMERGENCY POWER;

(9) AREAS WHERE LIFE SUPPORT EQUIPMENT IS USED;

(10) IF APPLICABLE, COMMON AREAS OR AREAS OF REFUGE; AND

(11) IF APPLICABLE, TOILET ROOMS OF COMMON AREAS OR AREAS OF REFUGE.

(E) EMERGENCY ELECTRICAL POWER SHALL BE PROVIDED FOR THE FOLLOWING:

(1) NURSES' CALL SYSTEM;