

(I) IF NOT LOCATED IN A BUILDING OPEN FOR PUBLIC USE, DOES NOT REQUIRE REGULAR FULL-TIME ATTENDANCE OR SCHEDULED VISITATION, IF THE LICENSEE:

1. IS RESPONSIBLE FOR THE SAFE OPERATION OF SUCH EQUIPMENT AT ALL TIMES;
2. IS AVAILABLE TO OBSERVE THE MONITORING EQUIPMENT OR DEVICES AND MAKE NECESSARY ADJUSTMENTS AT LEAST ONCE EVERY 24 HOURS; AND
3. MAINTAINS A DAILY INSPECTION LOG; AND

(II) IF LOCATED IN A SCHOOL, HOSPITAL, HOTEL, RESIDENTIAL FACILITY, OR OTHER BUILDING GENERALLY OPEN TO THE PUBLIC, IS VISITED AT LEAST ONCE EVERY 8 HOURS THAT THE BUILDING IS OPEN FOR PUBLIC USE, IF THE LICENSEE:

1. IS RESPONSIBLE FOR THE SAFE OPERATION OF SUCH EQUIPMENT AT ALL TIMES;
2. IS AVAILABLE TO OBSERVE THE MONITORING EQUIPMENT OR DEVICES AND MAKE NECESSARY ADJUSTMENTS AT LEAST ONCE EVERY 24 HOURS; AND
3. MAINTAINS A DAILY INSPECTION LOG.

(D) A GRADE 2 STATIONARY ENGINEER LICENSEE MAY OVERSEE THE OPERATION OF A BOILER THAT:

- (1) OPERATES AT A PRESSURE OF MORE THAN 15 PSI AND CAN OPERATE AT 300 TO 499 HORSEPOWER;
- (2) IS INSPECTED IN ACCORDANCE WITH THE BOILER LAWS AND REGULATIONS BY A SPECIAL INSPECTOR OR A DEPUTY BOILER INSPECTOR;
- (3) IF NOT EQUIPPED WITH A 24-HOUR COMPUTERIZED MONITORING SYSTEM AND AUTOMATIC CONTROLS, HAS A GRADE 2 LICENSEE IN ATTENDANCE AT ALL TIMES THAT THE BOILER IS IN OPERATION; AND
- (4) IF EQUIPPED WITH A 24-HOUR COMPUTERIZED MONITORING SYSTEM AND AUTOMATIC CONTROLS, IS ATTENDED BY A GRADE 2 LICENSEE AS FOLLOWS:

(I) IF NOT LOCATED IN A BUILDING OPEN FOR PUBLIC USE, DOES NOT REQUIRE REGULAR FULL-TIME ATTENDANCE OR SCHEDULED VISITATION, IF THE LICENSEE:

1. IS RESPONSIBLE FOR THE SAFE OPERATION OF SUCH EQUIPMENT AT ALL TIMES;