

2. IS AVAILABLE TO OBSERVE THE MONITORING EQUIPMENT OR DEVICES AND MAKE NECESSARY ADJUSTMENTS AT LEAST ONCE EVERY 24 HOURS; AND

3. MAINTAINS A DAILY INSPECTION LOG; AND

(II) IF LOCATED IN A SCHOOL, HOSPITAL, HOTEL, RESIDENTIAL FACILITY, OR OTHER BUILDING GENERALLY OPEN TO THE PUBLIC, IS VISITED AT LEAST ONCE EVERY 8 HOURS THAT THE BUILDING IS OPEN FOR PUBLIC USE, IF THE LICENSEE:

1. IS RESPONSIBLE FOR THE SAFE OPERATION OF SUCH EQUIPMENT AT ALL TIMES;

2. IS AVAILABLE TO OBSERVE THE MONITORING EQUIPMENT OR DEVICES AND MAKE NECESSARY ADJUSTMENTS AT LEAST ONCE EVERY 24 HOURS; AND

3. MAINTAINS A DAILY INSPECTION LOG.

(E) A GRADE 1 STATIONARY ENGINEER LICENSEE MAY OVERSEE THE OPERATION OF A BOILER THAT:

(1) OPERATES AT A PRESSURE OF MORE THAN 15 PSI AND CAN OPERATE AT 500 OR MORE HORSEPOWER;

(2) IS INSPECTED IN ACCORDANCE WITH THE BOILER LAWS AND REGULATIONS BY A SPECIAL INSPECTOR OR A DEPUTY BOILER INSPECTOR;

(3) IF NOT EQUIPPED WITH A 24-HOUR COMPUTERIZED MONITORING SYSTEM AND AUTOMATIC CONTROLS, HAS A GRADE 1 LICENSEE IN ATTENDANCE AT ALL TIMES THAT THE BOILER IS IN OPERATION; AND

(4) IF EQUIPPED WITH A 24-HOUR COMPUTERIZED MONITORING SYSTEM AND AUTOMATIC CONTROLS AND IS ATTENDED BY A GRADE 1 LICENSEE AS FOLLOWS:

(I) IF NOT LOCATED IN A BUILDING OPEN FOR PUBLIC USE, DOES NOT REQUIRE REGULAR VISITATION, IF THE LICENSEE:

1. IS RESPONSIBLE FOR THE SAFE OPERATION OF SUCH EQUIPMENT AT ALL TIMES;

2. IS AVAILABLE TO OBSERVE THE MONITORING EQUIPMENT OR DEVICES AND MAKE NECESSARY ADJUSTMENTS AT LEAST ONCE EVERY 24 HOURS; AND

3. MAINTAINS A DAILY INSPECTION LOG; AND

(II) IF LOCATED IN A SCHOOL, HOSPITAL, HOTEL, RESIDENTIAL FACILITY, OR OTHER BUILDING GENERALLY OPEN TO THE PUBLIC, IS VISITED AT LEAST ONCE EVERY 8 HOURS THAT THE BUILDING IS OPEN FOR PUBLIC USE, IF THE LICENSEE: