

(2) NITROGEN CONCENTRATIONS AND WEIGHTS SHALL BE CALCULATED ONLY DURING THE PERIOD OF APRIL 1 THROUGH OCTOBER 15 OF EACH YEAR AND THE NITROGEN REMOVAL REQUIREMENTS OF THIS SECTION ARE APPLICABLE ONLY DURING THIS PERIOD.

(B) ALL SEWAGE TREATMENT PLANTS DISCHARGING OVER 500,000 GALLONS OF WASTEWATER DAILY TO THE PATUXENT RIVER OR ANY OF ITS TRIBUTARIES SHALL:

(1) ON OR BEFORE JANUARY 1, 1989, REMOVE PHOSPHORUS TO A LEVEL OF NOT MORE THAN 1.0 MILLIGRAM PER LITER OF WASTEWATER EFFLUENT; AND

(2) ON OR BEFORE JULY 1, 1989, COMPLETE PLANS FOR THE REMOVAL--OF PLANNING TO ANTICIPATE THE NEED FOR THE FUTURE ADDITION OF FACILITIES TO REMOVE:

(I) PHOSPHORUS TO A LEVEL OF NOT MORE THAN 0.3 MILLIGRAM PER LITER OF WASTEWATER EFFLUENT; AND

(II) NITROGEN TO A LEVEL OF NOT MORE THAN 3.0 MILLIGRAMS PER LITER OF WASTEWATER EFFLUENT.

(C) ON OR BEFORE ~~JANUARY--17--1990~~ OCTOBER 1, 1991, THE PARKWAY SEWAGE TREATMENT PLANT AND THE WESTERN BRANCH SEWAGE TREATMENT PLANT SHALL REMOVE NITROGEN TO A LEVEL OF NOT MORE THAN 3.0 MILLIGRAMS PER LITER OF WASTEWATER EFFLUENT DISCHARGED INTO THE PATUXENT RIVER OR ANY OF ITS TRIBUTARIES.

(D) ON OR BEFORE ~~JANUARY--17--1990~~ OCTOBER 1, 1991, THE PATUXENT PLANT IN ANNE ARUNDEL COUNTY AND THE MARYLAND CITY PLANT SHALL:

(1) FOR THAT PORTION OF WASTEWATER FLOWS IN EXCESS OF THE 1981 AVERAGE DAILY FLOW, REMOVE NITROGEN TO A LEVEL OF NOT MORE THAN 3.0 MILLIGRAMS PER LITER OF WASTEWATER EFFLUENT DISCHARGED INTO THE PATUXENT RIVER OR ANY OF ITS TRIBUTARIES; OR

(2) REMOVE NITROGEN FROM THE TOTAL FLOW OF WASTEWATER EFFLUENT DISCHARGED INTO THE PATUXENT RIVER OR ANY OF ITS TRIBUTARIES, IF THE RESULTING LEVEL OF NITROGEN REDUCTION IS EQUIVALENT TO NITROGEN REDUCTION ACHIEVED UNDER ITEM (1) OF THIS SUBSECTION.

4-313.1.

(A) (1) THE DEPARTMENT SHALL IMPOSE AN ADMINISTRATIVE CIVIL PENALTY ON A PERSON WHO OWNS OR OPERATES A SEWAGE TREATMENT PLANT THAT IS IN VIOLATION OF § 4-302.1(B)(1), (C), OR (D) OF THIS SUBTITLE.

(2) THE PERSON ACCUSED OF THE VIOLATION SHALL HAVE THE RIGHT TO A HEARING BUT MAY WAIVE THAT RIGHT IN WRITING.