

- (I) TORCHIERE LIGHTING FIXTURES;
- (II) UNIT HEATERS;
- (III) LOW-VOLTAGE DRY-TYPE DISTRIBUTION TRANSFORMERS;
- (IV) CEILING FANS AND CEILING FAN LIGHT KITS;
- (V) RED AND GREEN TRAFFIC SIGNAL MODULES;
- (VI) ILLUMINATED EXIT SIGNS;
- (VII) COMMERCIAL REFRIGERATION CABINETS;
- (VIII) LARGE PACKAGED AIR-CONDITIONING EQUIPMENT; AND
- (IX) ~~SET TOP BOXES; AND~~
- ~~(X) COMMERCIAL CLOTHES WASHERS.~~

(2) THIS SECTION DOES NOT APPLY TO:

(I) NEW PRODUCTS MANUFACTURED IN THE STATE AND SOLD OUTSIDE THE STATE;

(II) NEW PRODUCTS MANUFACTURED OUTSIDE THE STATE AND SOLD AT WHOLESALE INSIDE THE STATE FOR FINAL RETAIL SALE AND INSTALLATION OUTSIDE THE STATE;

(III) PRODUCTS INSTALLED IN MOBILE MANUFACTURED HOMES AT THE TIME OF CONSTRUCTION; OR

(IV) PRODUCTS DESIGNED EXPRESSLY FOR INSTALLATION AND USE IN RECREATIONAL VEHICLES.

(C) (1) ON OR BEFORE JANUARY 1, 2004, THE ADMINISTRATION SHALL ADOPT REGULATIONS ESTABLISHING MINIMUM EFFICIENCY STANDARDS FOR THE TYPES OF NEW PRODUCTS SET FORTH IN SUBSECTION (B)(1) OF THIS SECTION.

(2) THE REGULATIONS SHALL PROVIDE FOR THE FOLLOWING MINIMUM EFFICIENCY STANDARDS:

(I) TORCHIERE FIXTURES MAY NOT CONSUME MORE THAN 190 WATTS AND MAY NOT BE CAPABLE OF OPERATING WITH LAMPS THAT TOTAL MORE THAN 190 WATTS;

(II) UNIT HEATERS MAY NOT HAVE PILOT LIGHTS AND SHALL HAVE EITHER POWER VENTING OR AN AUTOMATIC FLUE DAMPER;

(III) THE EFFICIENCY OF ALL LOW-VOLTAGE DRY-TYPE DISTRIBUTION TRANSFORMERS ~~SHALL BE NOT~~ MAY NOT BE LESS THAN THE VALUES SHOWN IN TABLE 4-2 OF NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION STANDARD TP-1-2002;