

(VI) ILLUMINATED EXIT SIGNS SHALL MEET THE REQUIREMENTS OF THE "ENERGY STAR PROGRAM REQUIREMENTS FOR EXIT SIGNS" DEVELOPED BY THE U.S. ENVIRONMENTAL PROTECTION AGENCY ~~AND THAT TOOK EFFECT ON JANUARY 1, 1999;~~

(VII) COMMERCIAL REFRIGERATION CABINETS SHALL MEET THE REQUIREMENTS SHOWN IN THE FOLLOWING TABLE IN WHICH "V" MEANS TOTAL VOLUME IN CUBIC FEET AND "AV" MEANS ADJUSTED VOLUME WHICH IS THE SUM OF THE VOLUME OF REFRIGERATED SPACE AND 1.63 TIMES THE VOLUME OF FREEZER SPACE:

EQUIPMENT TYPE	MAXIMUM DAILY ENERGY CONSUMPTION (KILOWATT HOURS)
REACH-IN CABINETS, PASS-THROUGH CABINETS, AND ROLL-IN OR ROLL-THROUGH CABINETS THAT ARE REFRIGERATORS WITH SOLID DOORS	0.125V + 2.76
REACH-IN CABINETS, PASS-THROUGH CABINETS, AND ROLL-IN OR ROLL-THROUGH CABINETS THAT ARE REFRIGERATORS WITH TRANSPARENT DOORS	0.172V + 4.77
REACH-IN CABINETS, PASS-THROUGH CABINETS, AND ROLL-IN OR ROLL-THROUGH CABINETS THAT ARE FREEZERS WITH SOLID DOORS	0.398V + 2.28
REACH-IN CABINETS, PASS-THROUGH CABINETS, AND ROLL-IN OR ROLL-THROUGH CABINETS THAT ARE FREEZERS WITH TRANSPARENT DOORS	0.940V + 5.10
REACH-IN CABINETS THAT ARE REFRIGERATOR-FREEZERS WITH SOLID DOORS	0.273AV + 1.65

(VIII) LARGE PACKAGED AIR-CONDITIONING EQUIPMENT SHALL MEET THE TIER II REQUIREMENTS OF THE "MINIMUM EQUIPMENT EFFICIENCIES FOR UNITARY COMMERCIAL AIR CONDITIONERS" OR "MINIMUM EQUIPMENT EFFICIENCIES FOR HEAT PUMPS", AS APPROPRIATE, DEVELOPED BY THE CONSORTIUM FOR ENERGY EFFICIENCY, BOSTON, MASSACHUSETTS, AS IN EFFECT ON JANUARY 1, 2002; AND

~~(IX) SET TOP BOXES SHALL MEET THE TIER 2 CRITERIA OF THE "ENERGY STAR PROGRAM REQUIREMENTS FOR SET TOP BOXES" DEVELOPED BY THE U.S. ENVIRONMENTAL PROTECTION AGENCY AND THAT TOOK EFFECT ON JANUARY 1, 2001; AND~~

~~(X)~~ (IX) COMMERCIAL CLOTHES WASHERS SHALL HAVE A MINIMUM MODIFIED ENERGY FACTOR OF 1.26 AND A MAXIMUM WATER CONSUMPTION FACTOR OF 9.5, AS MEASURED IN ACCORDANCE WITH THE FEDERAL TEST METHOD FOR CLOTHES WASHERS AS DEFINED IN 10 C.F.R. SECTION 430.23(J) (APPENDIX J1 TO SUBPART B OF PART 430) (2001).