

STANDARDS FOR CARBON MONOXIDE DEVICES LISTED AND CARRIES THE LISTING OF A NATIONALLY RECOGNIZED TESTING LABORATORY APPROVED BY THE OFFICE OF THE STATE FIRE MARSHAL; AND

~~(5) (4) IS BATTERY POWERED, A PLUG-IN TYPE WITH BATTERY BACKUP, OR WIRED INTO AN ALTERNATING CURRENT (AC) POWERLINE WITH SECONDARY BATTERY BACKUP.~~

(C) (1) “DWELLING” MEANS A BUILDING OR PART OF A BUILDING THAT PROVIDES LIVING OR SLEEPING FACILITIES FOR ONE OR MORE INDIVIDUALS.

(2) “DWELLING” INCLUDES A ONE OR TWO FAMILY DWELLING, MULTIFAMILY DWELLING, HOTEL, MOTEL, OR DORMITORY.

(D) “INSTALL” MEANS:

~~(1) IF BATTERY POWERED, TO ATTACH TO THE WALL OR CEILING OF A DWELLING IN ACCORDANCE WITH THE MOST RECENT STANDARDS OF:~~

~~(1) THE NATIONAL FIRE PROTECTION ASSOCIATION RELATED TO (NFPA) 720 STANDARD FOR THE INSTALLATION OF CARBON MONOXIDE WARNING EQUIPMENT IN DWELLING UNITS; AND~~

~~(2) TO PLUG DIRECTLY INTO AN ELECTRICAL OUTLET THAT IS NOT CONTROLLED BY A SWITCH; OR~~

~~(3) TO HARDWIRE INTO AN ALTERNATING CURRENT (AC) ELECTRICAL SERVICE THE MANUFACTURER’S RECOMMENDATIONS.~~

12-1102.

THIS SUBTITLE ONLY APPLIES TO A ~~SINGLE FAMILY OR MULTIFAMILY DWELLING THAT:~~

(1) RELIES ON THE COMBUSTION OF A FOSSIL FUEL FOR HEAT, VENTILATION, OR HOT WATER, OR CLOTHES DRYER OPERATION; OR AND

~~(2) IS CONNECTED TO A GARAGE.~~

(2) IS A NEWLY CONSTRUCTED DWELLING FOR WHICH A BUILDING PERMIT IS ISSUED ON OR AFTER JANUARY 1, 2008.