

(3) if not equipped with a 24-hour computerized monitoring system and automatic controls, is visited by a Grade 5 licensee at least once every 24 hours that the boiler is in operation; and

(4) if equipped with a 24-hour computerized monitoring system and automatic controls, is visited by a Grade 5 licensee at least once per week that the boiler is in operation, if the licensee:

(i) is responsible for the safe operation of the equipment at all times;

(ii) is available to observe the monitoring equipment or devices and make the necessary adjustments at least once every 24 hours; and

(iii) maintains a daily inspection log.

(b) A Grade 4 stationary engineer licensee may oversee the operation of a ~~POWER BOILER OR A HIGH PRESSURE, HIGH TEMPERATURE~~ boiler that:

(1) (i) [operates at a pressure of more than 15 psi and] can operate at 30 to 99 horsepower; and

(ii) is located in a building open for public use;

(2) is inspected in accordance with the boiler laws and regulations by a special inspector or a deputy boiler inspector;

(3) if not equipped with a 24-hour computerized monitoring system and automatic controls, is attended by a Grade 4 licensee as follows:

(i) at all times that the boiler is in operation; or

(ii) if located in a school:

1. at all times during regular school hours; and

2. only when at least 150 students, faculty, or members of the public occupy the building where the boiler is located during nonregular school hours;

(4) if equipped with a 24-hour computerized monitoring system and automatic controls, is attended by a Grade 4 licensee as follows: