- (i) if located in a hospital, hotel, residential facility, or other building generally open to the public, is visited at least once every 8 hours that the building is open for public use, if the licensee:
- 1. is responsible for the safe operation of such equipment at all times;
- 2. is available to observe the monitoring equipment or devices and make necessary adjustments at least once every 24 hours; and
 - 3. maintains a daily inspection log; and
 - (ii) if located in a school, is visited at least once every 8 hours:
 - 1. during regular school hours; and
- 2. during nonregular school hours when the school building in which the boiler is located is occupied by at least 150 students, faculty, or members of the public, if the licensee:
- A. is responsible for the safe operation of such equipment at all times:
- B. is available to observe the monitoring equipment or devices and make necessary adjustments at least once every 24 hours; and
 - C. maintains a daily inspection log.
- (c) A Grade 3 stationary engineer licensee may oversee the operation of a **POWER BOILER OR A HIGH PRESSURE, HIGH TEMPERATURE** boiler that:
- (1) [operates at a pressure of more than 15 psi and] can operate at 100 to 299 horsepower;
- (2) is inspected in accordance with the boiler laws and regulations by a special inspector or a deputy boiler inspector;
- (3) if not equipped with a 24-hour computerized monitoring system and automatic controls, has a Grade 3 licensee in attendance at all times that the boiler is in operation; and
- (4) if equipped with a 24-hour computerized monitoring system and automatic controls, is attended by a Grade 3 licensee as follows: