

6.5-302.

(a) A Grade 5 stationary engineer licensee may oversee the operation of a ~~POWER BOILER OR A HIGH PRESSURE, HIGH TEMPERATURE WATER~~ boiler that:

- (1) (i) [operates at a pressure of more than 15 psi and] can be operated at 30 to 99 horsepower; and
 - (ii) is located in a building not open for public use;
- (2) is inspected in accordance with the boiler laws and regulations by a special inspector or a deputy boiler inspector;
- (3) if not equipped with a 24-hour computerized monitoring system and automatic controls, is visited by a Grade 5 licensee at least once every 24 hours that the boiler is in operation; and
- (4) if equipped with a 24-hour computerized monitoring system and automatic controls, is visited by a Grade 5 licensee at least once per week that the boiler is in operation, if the licensee:

- (i) is responsible for the safe operation of the equipment at all times;
- (ii) is available to observe the monitoring equipment or devices and make the necessary adjustments at least once every 24 hours; and
- (iii) maintains a daily inspection log.

(b) A Grade 4 stationary engineer licensee may oversee the operation of a ~~POWER BOILER OR A HIGH PRESSURE, HIGH TEMPERATURE~~ boiler that:

- (1) (i) [operates at a pressure of more than 15 psi and] can operate at 30 to 99 horsepower; and
 - (ii) is located in a building open for public use;
- (2) is inspected in accordance with the boiler laws and regulations by a special inspector or a deputy boiler inspector;
- (3) if not equipped with a 24-hour computerized monitoring system and automatic controls, is attended by a Grade 4 licensee as follows:
 - (i) at all times that the boiler is in operation; or