

(ii) if located in a school:

1. at all times during regular school hours; and
2. only when at least 150 students, faculty, or members of the public occupy the building where the boiler is located during nonregular school hours;

(4) if equipped with a 24-hour computerized monitoring system and automatic controls, is attended by a Grade 4 licensee as follows:

(i) if located in a hospital, hotel, residential facility, or other building generally open to the public, is visited at least once every 8 hours that the building is open for public use, if the licensee:

1. is responsible for the safe operation of such equipment at all times;
2. is available to observe the monitoring equipment or devices and make necessary adjustments at least once every 24 hours; and
3. maintains a daily inspection log; and

(ii) if located in a school, is visited at least once every 8 hours:

1. during regular school hours; and
2. during nonregular school hours when the school building in which the boiler is located is occupied by at least 150 students, faculty, or members of the public, if the licensee:

- A. is responsible for the safe operation of such equipment at all times;
- B. is available to observe the monitoring equipment or devices and make necessary adjustments at least once every 24 hours; and
- C. maintains a daily inspection log.

(c) A Grade 3 stationary engineer licensee may oversee the operation of a ~~POWER BOILER OR A HIGH PRESSURE, HIGH TEMPERATURE~~ boiler that:

- (1) [operates at a pressure of more than 15 psi and] can operate at 100 to 299 horsepower;