

(g) (1) Within 24 hours after an accident or explosion, the owner or user of a boiler or pressure vessel shall give the Chief Boiler Inspector notice of the accident or explosion in accordance with regulations adopted under this subtitle.

(2) On notification or information, the Chief Boiler Inspector or a deputy boiler inspector shall investigate each accident or explosion that involves a boiler or pressure vessel covered by this subtitle.

(h) (1) The Board shall provide for public safety and therefore has jurisdiction over the interpretation and application of the inspection requirements provided in the regulations adopted under this subtitle.

(2) Inspection requirements of operating equipment shall:

(i) be in accordance with generally accepted practice; and

(ii) be compatible with the actual service conditions, including:

1. previous experience, based on records of performance and maintenance;
2. location, with respect to personnel hazard;
3. provision for related safe operation controls; and
4. interrelation with other operations outside the scope of this subtitle.

(i) The owner or user of a boiler or pressure vessel required by this subtitle to be inspected by the Chief Boiler Inspector or a deputy boiler inspector shall pay directly to the Chief Boiler Inspector, on completion of the inspection, a fee in accordance with the following schedule:

(1) certificate inspection:

(i) initial certificate inspection of a boiler or pressure vessel not previously inspected in the State..... no charge

(ii) certificate inspection of a boiler or pressure vessel, other than a pressure vessel attached to an air compressor, previously inspected in the State..... \$40

(iii) certificate inspection of a pressure vessel, attached to an air compressor, previously inspected in the State..... \$10