

~~(HH)~~ (IV) IF THE REPORT OF THE PRIVATE INSPECTOR SHOWS THAT THE EXHIBITION OR ANTIQUE BOILER OR PRESSURE VESSEL COMPLIES WITH THE REQUIREMENTS OF SUBSECTION (D) OF THIS SECTION AND THE REGULATIONS ADOPTED UNDER THIS SUBTITLE, THE CHIEF BOILER INSPECTOR SHALL ISSUE A CERTIFICATE TO THE OWNER OR USER OF THE EXHIBITION OR ANTIQUE BOILER OR PRESSURE VESSEL THAT AUTHORIZES IT TO BE USED IN AN EXHIBIT OR SHOW FOR NONCOMMERCIAL PURPOSES.

(d) (1) Except for boilers and pressure vessels exempt under subsection (a) of this section or § 12-903 of this subtitle, each boiler and each pressure vessel that is used or proposed to be used in the State shall be inspected thoroughly as to its construction, installation, and condition in accordance with this subsection.

(2) A certificate inspection required under this subsection shall be:

- (i) an internal inspection if construction allows; or
- (ii) an inspection that is as complete as possible.

(3) (i) Except for model steam boilers, a power boiler or a high pressure, high temperature water boiler shall:

- 1. receive a certificate inspection annually; and
- 2. be externally inspected annually while under pressure, if possible.

(ii) The Board may extend to 2 years the interval between certificate inspections of a power boiler if:

1. the power boiler has internal continuous water treatment under the general supervision of a professional engineer who has experience in the treatment of boiler water; and

2. the owner or user of the power boiler keeps available, for examination by the Chief Boiler Inspector or by a deputy boiler inspector or special inspector, accurate records that show:

A. the date, time, and reason that the power boiler is out of service; and

B. a chemical and physical analysis of samples of the boiler water taken at regular intervals of not more than 48 hours of operation that adequately show the condition of the boiler water and any elements or characteristics